



## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

Community Middle School  
95 Grovers Mill Rd, Plainsboro Township, NJ 08536

Dear Community Middle School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Community Middle School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 24 samples taken, all but 6 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
1 <sup>st</sup> Floor Classroom 502 Home Economics Faucet #3 ID # CMS-1-502-EC3-P	24.1	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom 502 Home Economics Faucet #4 ID# CMS-1-502-EC4-P	106	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
1 <sup>st</sup> Floor Classroom 401 Sprayer ID# CMS-1-401-SP-P	78.1	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom 315 Faucet ID# CMS-1-315-CF-P	113	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom 314 Faucet ID# CMS-1-314-CF-P	108	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom 302 Sprayer ID# CMS-1-302-SP-P	55.3	Disconnected outlet until further notice

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Community Middle School, 95 Grovers Mill Rd., Middlesex

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
CMS-Field Blank	N	P21-09469-01	PAS	NJDEP 15001	8/25/2021	5:05	SM 3113 B	8/30/2021	7:05	-0.47	2.00	1	N	ND
CMS-1-502-EC1-P	N	P21-09469-02	PAS	NJDEP 15001	8/25/2021	5:06	SM 3113 B	8/30/2021	7:09	0.031	2.00	1	N	ND
CMS-1-502-EC2-P	N	P21-09469-03	PAS	NJDEP 15001	8/25/2021	5:06	SM 3113 B	8/30/2021	7:13	1.03	2.00	1	N	J
CMS-1-502-EC3-P	N	P21-09469-04	PAS	NJDEP 15001	8/25/2021	5:06	SM 3113 B	8/30/2021	8:18	24.1	4.00	2	N	
CMS-1-502-EC4-P	N	P21-09469-05	PAS	NJDEP 15001	8/25/2021	5:06	SM 3113 B	8/30/2021	8:22	106	20.0	10	N	
CMS-1-502-EC5-P	N	P21-09469-06	PAS	NJDEP 15001	8/25/2021	5:07	SM 3113 B	8/30/2021	7:37	2.04	2.00	1	N	
CMS-1-502-EC6-P	N	P21-09469-07	PAS	NJDEP 15001	8/25/2021	5:07	SM 3113 B	8/30/2021	7:41	2.04	2.00	1	N	
CMS-1-502-EC7-P	N	P21-09469-08	PAS	NJDEP 15001	8/25/2021	5:07	SM 3113 B	8/30/2021	7:45	0.031	2.00	1	N	ND
CMS-1-501-CF-P	N	P21-09469-09	PAS	NJDEP 15001	8/25/2021	5:08	SM 3113 B	8/30/2021	7:49	-0.22	2.00	1	N	ND
CMS-1-401-CF-P	N	P21-09469-10	PAS	NJDEP 15001	8/25/2021	5:10	SM 3113 B	8/30/2021	7:53	4.29	2.00	1	N	
CMS-1-401-SP-P	N	P21-09469-11	PAS	NJDEP 15001	8/25/2021	5:10	SM 3113 B	8/30/2021	8:26	78.1	20.0	10	N	
CMS-1-H405-BT-P	N	P21-09469-12	PAS	NJDEP 15001	8/25/2021	5:12	SM 3113 B	8/30/2021	8:41	-0.22	2.00	1	N	ND
CMS-1-614-TL-P	N	P21-09469-13	PAS	NJDEP 15001	8/25/2021	5:16	SM 3113 B	8/30/2021	8:45	2.79	2.00	1	N	
CMS-1-324-TF-P	N	P21-09469-14	PAS	NJDEP 15001	8/25/2021	5:18	SM 3113 B	8/30/2021	8:49	1.03	2.00	1	N	J
CMS-1-315-CF-P	N	P21-09469-15	PAS	NJDEP 15001	8/25/2021	5:19	SM 3113 B	8/30/2021	10:01	113	20.0	10	N	
CMS-1-314-CF-P	N	P21-09469-16	PAS	NJDEP 15001	8/25/2021	5:20	SM 3113 B	8/30/2021	10:05	108	20.0	10	N	
CMS-1-313-CF-P	N	P21-09469-17	PAS	NJDEP 15001	8/25/2021	5:21	SM 3113 B	8/30/2021	9:09	11.1	2.00	1	N	
CMS-1-312-CF-P	N	P21-09469-18	PAS	NJDEP 15001	8/25/2021	5:23	SM 3113 B	8/30/2021	9:13	7.05	2.00	1	N	
CMS-1-305-TL-P	N	P21-09469-19	PAS	NJDEP 15001	8/25/2021	5:24	SM 3113 B	8/30/2021	9:17	0.530	2.00	1	N	ND
CMS-1-301-CF-P	N	P21-09469-20	PAS	NJDEP 15001	8/25/2021	5:24	SM 3113 B	8/30/2021	9:21	3.54	2.00	1	N	
CMS-1-302-CF-P	N	P21-09469-21	PAS	NJDEP 15001	8/25/2021	5:25	SM 3113 B	8/30/2021	9:26	2.04	2.00	1	N	
CMS-1-302-SP-P	N	P21-09469-22	PAS	NJDEP 15001	8/25/2021	5:26	SM 3113 B	8/30/2021	10:09	55.3	10.0	5	N	
CMS-1-304-CF-P	N	P21-09469-23	PAS	NJDEP 15001	8/25/2021	5:28	SM 3113 B	8/30/2021	9:34	3.54	2.00	1	N	
CMS-1-H206-BT-P	N	P21-09469-24	PAS	NJDEP 15001	8/25/2021	5:33	SM 3113 B	8/30/2021	10:14	0.280	2.00	1	N	ND

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)rimary / (F)lush

**OUTLET TYPE**

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib



## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

Dutch Neck Elementary School  
92 Village Rd E, West Windsor Township, NJ 08550

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Dutch Neck Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 48 samples taken, all but 5 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action the West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
1 <sup>st</sup> Floor Classroom Faucet ID # DNES-1-2-CF-P	37.0	Disconnected outlet until further notice
Kitchen Kettle Faucet ID# DNES-1-Kit-KT-P	137	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom Faucet ID # DNES-1-405-CF-P	25.7	Disconnected outlet until further notice
1 <sup>st</sup> Floor Nurse's Sink ID # DNES-1-Nurse 406-NS-P	1180	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
1 <sup>st</sup> Floor Nurse's Sink ID # DNES-1-Nurse 409-CF-P	22.7	Disconnected outlet until further notice

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

Thomas Daly, CEFM  
Director of Buildings & Grounds

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Dutch Neck Elementary, 392 Village Road East

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank	N	P21-08570-01	PAS	NJDEP 15001	8/10/2021	4:51	SM 3113 B	8/12/2021	8:41	-0.28	2.00	1	N	ND
DNES-1-103-CF2-P	N	P21-08570-02	PAS	NJDEP 15001	8/10/2021	4:52	SM 3113 B	8/12/2021	8:45	3.67	2.00	1	N	
DNES-1-103-CF-P	N	P21-08570-03	PAS	NJDEP 15001	8/10/2021	4:53	SM 3113 B	8/12/2021	9:09	7.63	2.00	1	N	
DNES-1-105-CF-P	N	P21-08570-04	PAS	NJDEP 15001	8/10/2021	4:55	SM 3113 B	8/12/2021	9:13	0.880	2.00	1	N	ND
DNES-1-100-CF-P	N	P21-08570-05	PAS	NJDEP 15001	8/10/2021	4:57	SM 3113 B	8/12/2021	9:16	1.81	2.00	1	N	J
DNES-1-MO-TL-P	N	P21-08570-06	PAS	NJDEP 15001	8/10/2021	4:59	SM 3113 B	8/12/2021	9:20	2.98	2.00	1	N	
DNES-1-Faculty-TL-P	N	P21-08570-07	PAS	NJDEP 15001	8/10/2021	5:00	SM 3113 B	8/12/2021	9:24	0.650	2.00	1	N	ND
<b>DNES-1-2-CF-P</b>	<b>N</b>	<b>P21-08570-08</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/10/2021</b>	<b>5:02</b>	<b>SM 3113 B</b>	<b>8/12/2021</b>	<b>13:09</b>	<b>37.0</b>	<b>8.00</b>	<b>4</b>	<b>N</b>	
DNES-1-4-CF-P	N	P21-08570-09	PAS	NJDEP 15001	8/10/2021	5:03	SM 3113 B	8/12/2021	13:05	2.28	2.00	1	N	
DNES-1-5-CF-P	N	P21-08570-10	PAS	NJDEP 15001	8/10/2021	5:03	SM 3113 B	8/12/2021	9:36	4.60	2.00	1	N	
DNES-1-6-CF-P	N	P21-08570-11	PAS	NJDEP 15001	8/10/2021	5:04	SM 3113 B	8/12/2021	9:41	2.51	2.00	1	N	
DNES-1-7-CF-P	N	P21-08570-12	PAS	NJDEP 15001	8/10/2021	5:06	SM 3113 B	8/12/2021	9:53	6.70	2.00	1	N	
DNES-1-8-CF-P	N	P21-08570-13	PAS	NJDEP 15001	8/10/2021	5:08	SM 3113 B	8/12/2021	9:57	3.67	2.00	1	N	
DNES-1-10-CF-P	N	P21-08570-14	PAS	NJDEP 15001	8/10/2021	5:08	SM 3113 B	8/12/2021	10:01	3.21	2.00	1	N	
DNES-1-Storage Across 10/12-CF-P	N	P21-08570-15	PAS	NJDEP 15001	8/10/2021	5:09	SM 3113 B	8/12/2021	10:05	1.58	2.00	1	N	J
DNES-1-12-CF-P	N	P21-08570-16	PAS	NJDEP 15001	8/10/2021	5:10	SM 3113 B	8/12/2021	10:09	1.35	2.00	1	N	J
DNES-1-Kit-FP1-P	N	P21-08570-17	PAS	NJDEP 15001	8/10/2021	5:13	SM 3113 B	8/12/2021	10:13	0.880	2.00	1	N	ND
DNES-1-Kit-FP2-P	N	P21-08570-18	PAS	NJDEP 15001	8/10/2021	5:13	SM 3113 B	8/12/2021	10:19	1.12	2.00	1	N	J
<b>DNES-1-Kit-KT-P</b>	<b>N</b>	<b>P21-08570-19</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/10/2021</b>	<b>5:14</b>	<b>SM 3113 B</b>	<b>8/12/2021</b>	<b>13:13</b>	<b>137</b>	<b>100</b>	<b>50</b>	<b>N</b>	
DNES-1-Nurse-NS-P	N	P21-08570-20	PAS	NJDEP 15001	8/10/2021	5:16	SM 3113 B	8/12/2021	10:42	5.07	2.00	1	N	
DNES-1-H Roof-BT-P	N	P21-08570-21	PAS	NJDEP 15001	8/10/2021	5:18	SM 3113 B	8/12/2021	10:54	0.190	2.00	1	N	ND
DNES-1-14-CF-P	N	P21-08570-22	PAS	NJDEP 15001	8/10/2021	5:19	SM 3113 B	8/12/2021	10:58	4.14	2.00	1	N	
DNES-1-15-CF-P	N	P21-08570-23	PAS	NJDEP 15001	8/10/2021	5:20	SM 3113 B	8/12/2021	11:02	4.37	2.00	1	N	
DNES-1-17-CF-P	N	P21-08570-24	PAS	NJDEP 15001	8/10/2021	5:20	SM 3113 B	8/12/2021	11:06	5.30	2.00	1	N	
DNES-1-20-CF-P	N	P21-08570-25	PAS	NJDEP 15001	8/10/2021	5:21	SM 3113 B	8/12/2021	11:10	0.650	2.00	1	N	ND
DNES-1-19-CF-P	N	P21-08570-26	PAS	NJDEP 15001	8/10/2021	5:22	SM 3113 B	8/12/2021	11:14	1.58	2.00	1	N	J
DNES-1-21-CF-P	N	P21-08570-27	PAS	NJDEP 15001	8/10/2021	5:23	SM 3113 B	8/12/2021	11:26	1.81	2.00	1	N	J
DNES-1-23-CF-P	N	P21-08570-28	PAS	NJDEP 15001	8/10/2021	5:24	SM 3113 B	8/12/2021	11:30	1.35	2.00	1	N	J
DNES-1-25-CF-P	N	P21-08570-29	PAS	NJDEP 15001	8/10/2021	5:25	SM 3113 B	8/12/2021	11:33	1.58	2.00	1	N	J
DNES-1-27-CF-P	N	P21-08570-30	PAS	NJDEP 15001	8/10/2021	5:25	SM 3113 B	8/12/2021	11:37	4.60	2.00	1	N	
DNES-1-401-CF-P	N	P21-08570-31	PAS	NJDEP 15001	8/10/2021	5:29	SM 3113 B	8/12/2021	11:41	1.35	2.00	1	N	J
DNES-1-403-CF-P	N	P21-08570-32	PAS	NJDEP 15001	8/10/2021	5:30	SM 3113 B	8/12/2021	11:46	2.74	2.00	1	N	
<b>DNES-1-405-CF-P</b>	<b>N</b>	<b>P21-08570-33</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/10/2021</b>	<b>5:31</b>	<b>SM 3113 B</b>	<b>8/12/2021</b>	<b>13:17</b>	<b>25.7</b>	<b>6.00</b>	<b>3</b>	<b>N</b>	
<b>DNES-1-Nurse 406-NS-P</b>	<b>N</b>	<b>P21-08570-34</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/10/2021</b>	<b>5:31</b>	<b>SM 3113 B</b>	<b>8/12/2021</b>	<b>13:38</b>	<b>1180</b>	<b>200</b>	<b>100</b>	<b>N</b>	
DNES-1-Nurse 407-NS-P	N	P21-08570-35	PAS	NJDEP 15001	8/10/2021	5:33	SM 3113 B	8/12/2021	12:18	2.74	2.00	1	N	
<b>DNES-1-Nurse 408-NS-P</b>	<b>N</b>	<b>P21-08570-36</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/10/2021</b>	<b>5:34</b>	<b>SM 3113 B</b>	<b>8/12/2021</b>	<b>12:34</b>	<b>13.4</b>	<b>2.00</b>	<b>1</b>	<b>Y</b>	
<b>DNES-1-Nurse 409-NS-P</b>	<b>N</b>	<b>P21-08570-37</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/10/2021</b>	<b>5:34</b>	<b>SM 3113 B</b>	<b>8/12/2021</b>	<b>12:42</b>	<b>22.7</b>	<b>4.00</b>	<b>2</b>	<b>N</b>	
DNES-1-301-CF-P	N	P21-08570-38	PAS	NJDEP 15001	8/10/2021	5:37	SM 3113 B	8/12/2021	12:45	1.58	2.00	1	N	J
DNES-1-300-CF-P	N	P21-08570-39	PAS	NJDEP 15001	8/10/2021	5:38	SM 3113 B	8/12/2021	12:49	0.190	2.00	1	N	ND
DNES-1-303-CF-P	N	P21-08570-40	PAS	NJDEP 15001	8/10/2021	5:39	SM 3113 B	8/12/2021	12:53	-0.28	2.00	1	N	ND
DNES-1-302-CF-P	N	P21-08570-41	PAS	NJDEP 15001	8/10/2021	5:40	SM 3113 B	8/12/2021	7:57	0.370	2.00	1	N	ND
DNES-1-305-CF-P	N	P21-08570-42	PAS	NJDEP 15001	8/10/2021	5:40	SM 3113 B	8/12/2021	8:35	0.420	2.00	1	N	ND
DNES-1-304-CF-P	N	P21-08570-43	PAS	NJDEP 15001	8/10/2021	5:41	SM 3113 B	8/12/2021	8:39	3.29	2.00	1	N	
DNES-2-201-CF-P	N	P21-08570-44	PAS	NJDEP 15001	8/10/2021	5:44	SM 3113 B	8/12/2021	8:42	1.09	2.00	1	N	J
DNES-2-202-CF-P	N	P21-08570-45	PAS	NJDEP 15001	8/10/2021	5:45	SM 3113 B	8/12/2021	8:46	2.48	2.00	1	N	
DNES-2-203-CF-P	N	P21-08570-46	PAS	NJDEP 15001	8/10/2021	5:46	SM 3113 B	8/12/2021	8:49	2.86	2.00	1	N	
DNES-2-204-CF-P	N	P21-08570-47	PAS	NJDEP 15001	8/10/2021	5:47	SM 3113 B	8/12/2021	8:53	0.850	2.00	1	N	ND
DNES-2-205-CF-P	N	P21-08570-48	PAS	NJDEP 15001	8/10/2021	5:48	SM 3113 B	8/12/2021	8:56	0.610	2.00	1	N	ND

**Exceeds EPA Action Limit (> 15.5ppb)**

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

**OUTLET TYPE**

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib





## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

Grover Middle School  
10 Southfield Road, West Windsor Township, NJ 08550

Dear Grover Middle School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Grover Middle School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15  $\mu\text{g/l}$  (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 66 samples taken, all but 3 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15  $\mu\text{g/l}$  [ppb]).

The table below identifies the drinking water outlets that tested above the 15  $\mu\text{g/l}$  for lead, the actual lead level, and what temporary remedial action the West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in <math>\mu\text{g/l}</math> (ppb)</b>	<b>Remedial Action</b>
1 <sup>st</sup> Floor Classroom E133 Faucet ID # GMS-1-E133-CF-P	24.3	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom B118 Faucet ID# GMS-1-B118-CF-P	59.5	Disconnected outlet until further notice
2 <sup>nd</sup> Floor Classroom A232 Faucet ID # GMS-2-A232-CF-P	22.1	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

## Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

## Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

## For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Grover Middle School, 10 Southfield Road

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank	N	P21-08957-01	PAS	NJDEP 15001	8/17/2021	4:56	SM 3113 B	8/18/2021	8:13	-0.21	2.00	1	N	ND
GMS-1-C118-TL-P	N	P21-08957-02	PAS	NJDEP 15001	8/17/2021	4:56	SM 3113 B	8/18/2021	8:17	0.0055	2.00	1	N	ND
GMS-1-C128-CF-P	N	P21-08957-03	PAS	NJDEP 15001	8/17/2021	4:57	SM 3113 B	8/18/2021	8:41	1.77	2.00	1	N	J
GMS-1-C155-CF-P	N	P21-08957-04	PAS	NJDEP 15001	8/17/2021	4:59	SM 3113 B	8/18/2021	8:45	1.33	2.00	1	N	J
GMS-1-Nurse-NS-P	N	P21-08957-05	PAS	NJDEP 15001	8/17/2021	5:05	SM 3113 B	8/18/2021	8:49	0.230	2.00	1	N	ND
GMS-1-CAF-BT1-P	N	P21-08957-06	PAS	NJDEP 15001	8/17/2021	5:07	SM 3113 B	8/18/2021	8:53	-0.21	2.00	1	N	ND
GMS-1-C106-TL-P	N	P21-08957-07	PAS	NJDEP 15001	8/17/2021	5:08	SM 3113 B	8/18/2021	8:56	0.670	2.00	1	N	ND
GMS-1-Kit-FP1-P	N	P21-08957-08	PAS	NJDEP 15001	8/17/2021	5:09	SM 3113 B	8/18/2021	9:00	1.99	2.00	1	N	J
GMS-1-Kit-FP2-P	N	P21-08957-09	PAS	NJDEP 15001	8/17/2021	5:10	SM 3113 B	8/18/2021	9:04	3.97	2.00	1	N	ND
GMS-1-Kit-FP3-P	N	P21-08957-10	PAS	NJDEP 15001	8/17/2021	5:11	SM 3113 B	8/18/2021	9:09	0.670	2.00	1	N	ND
GMS-1-Kit-KT-P	N	P21-08957-11	PAS	NJDEP 15001	8/17/2021	5:12	SM 3113 B	8/18/2021	9:13	9.70	2.00	1	N	ND
GMS-1-Kit-IM-P	N	P21-08957-12	PAS	NJDEP 15001	8/17/2021	5:13	SM 3113 B	8/18/2021	9:25	-0.21	2.00	1	N	ND
GMS-1-MOD105-TL-P	N	P21-08957-13	PAS	NJDEP 15001	8/17/2021	5:16	SM 3113 B	8/18/2021	9:29	-0.21	2.00	1	N	ND
GMS-1-HD160-BT-P	N	P21-08957-14	PAS	NJDEP 15001	8/17/2021	5:18	SM 3113 B	8/18/2021	9:33	-0.21	2.00	1	N	ND
GMS-1-E119-TL-P	N	P21-08957-15	PAS	NJDEP 15001	8/17/2021	5:20	SM 3113 B	8/18/2021	9:37	1.55	2.00	1	N	J
GMS-1-E144-CF-P	N	P21-08957-16	PAS	NJDEP 15001	8/17/2021	5:22	SM 3113 B	8/18/2021	9:41	0.450	2.00	1	N	ND
GMS-1-HE143-BT-P	N	P21-08957-17	PAS	NJDEP 15001	8/17/2021	5:23	SM 3113 B	8/18/2021	9:45	-0.21	2.00	1	N	ND
GMS-1-E140-CF-P	N	P21-08957-18	PAS	NJDEP 15001	8/17/2021	5:24	SM 3113 B	8/18/2021	9:50	1.33	2.00	1	N	J
GMS-1-E139-CF-P	N	P21-08957-19	PAS	NJDEP 15001	8/17/2021	5:24	SM 3113 B	8/18/2021	9:54	0.890	2.00	1	N	ND
<b>GMS-1-E133-CF-P</b>	<b>N</b>	<b>P21-08957-20</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/17/2021</b>	<b>5:25</b>	<b>SM 3113 B</b>	<b>8/18/2021</b>	<b>12:03</b>	<b>24.3</b>	<b>4.00</b>	<b>2</b>	<b>N</b>	
GMS-1-E129-CF-P	N	P21-08957-21	PAS	NJDEP 15001	8/17/2021	5:26	SM 3113 B	8/18/2021	10:10	3.31	2.00	1	N	ND
GMS-1-E130-CF-P	N	P21-08957-22	PAS	NJDEP 15001	8/17/2021	5:26	SM 3113 B	8/18/2021	10:26	0.450	2.00	1	N	ND
GMS-1-E132-CF-P	N	P21-08957-23	PAS	NJDEP 15001	8/17/2021	5:27	SM 3113 B	8/18/2021	10:30	1.33	2.00	1	N	J
GMS-1-E124-CF-P	N	P21-08957-24	PAS	NJDEP 15001	8/17/2021	5:29	SM 3113 B	8/18/2021	10:34	2.43	2.00	1	N	ND
<b>GMS-1-B118-CF-P</b>	<b>N</b>	<b>P21-08957-25</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/17/2021</b>	<b>5:29</b>	<b>SM 3113 B</b>	<b>8/18/2021</b>	<b>12:07</b>	<b>59.5</b>	<b>10.0</b>	<b>5</b>	<b>N</b>	
GMS-1-D146-CF-P	N	P21-08957-26	PAS	NJDEP 15001	8/17/2021	5:31	SM 3113 B	8/18/2021	10:41	1.11	2.00	1	N	J
GMS-1-LoungeB115-TL-P	N	P21-08957-27	PAS	NJDEP 15001	8/17/2021	5:32	SM 3113 B	8/18/2021	10:54	0.230	2.00	1	N	ND
GMS-1-B102-CF-P	N	P21-08957-28	PAS	NJDEP 15001	8/17/2021	5:35	SM 3113 B	8/18/2021	10:57	3.09	2.00	1	N	ND
GMS-1-B105-CF-P	N	P21-08957-29	PAS	NJDEP 15001	8/17/2021	5:37	SM 3113 B	8/18/2021	11:01	0.230	2.00	1	N	ND
GMS-1-A141-CF-P	N	P21-08957-30	PAS	NJDEP 15001	8/17/2021	5:39	SM 3113 B	8/18/2021	11:05	2.65	2.00	1	N	ND
GMS-1-A149-TL-P	N	P21-08957-31	PAS	NJDEP 15001	8/17/2021	5:40	SM 3113 B	8/18/2021	11:09	1.55	2.00	1	N	J
GMS-1-A130-CF-P	N	P21-08957-32	PAS	NJDEP 15001	8/17/2021	5:41	SM 3113 B	8/18/2021	11:13	4.63	2.00	1	N	ND
GMS-1-A134-CF-P	N	P21-08957-33	PAS	NJDEP 15001	8/17/2021	5:43	SM 3113 B	8/18/2021	11:18	3.53	2.00	1	N	ND
GMS-1-A133-CF-P	N	P21-08957-34	PAS	NJDEP 15001	8/17/2021	5:44	SM 3113 B	8/18/2021	11:22	9.04	2.00	1	N	ND
GMS-1-A131-CF-P	N	P21-08957-35	PAS	NJDEP 15001	8/17/2021	5:45	SM 3113 B	8/18/2021	11:39	5.07	2.00	1	N	ND
GMS-1-A124-CF-P	N	P21-08957-36	PAS	NJDEP 15001	8/17/2021	5:45	SM 3113 B	8/18/2021	11:43	8.16	2.00	1	N	ND
GMS-1-A123-CF-P	N	P21-08957-37	PAS	NJDEP 15001	8/17/2021	5:46	SM 3113 B	8/18/2021	11:47	4.63	2.00	1	N	ND
GMS-1-HA120-BT-P	N	P21-08957-38	PAS	NJDEP 15001	8/17/2021	5:46	SM 3113 B	8/18/2021	11:51	0.0055	2.00	1	N	ND
GMS-1-A120-CF-P	N	P21-08957-39	PAS	NJDEP 15001	8/17/2021	5:47	SM 3113 B	8/18/2021	11:55	0.670	2.00	1	N	ND
GMS-1-A119-CF-P	N	P21-08957-40	PAS	NJDEP 15001	8/17/2021	5:48	SM 3113 B	8/18/2021	11:59	2.21	2.00	1	N	ND
GMS-1-A108-EC-P	N	P21-08957-41	PAS	NJDEP 15001	8/17/2021	5:49	SM 3113 B	8/18/2021	9:06	2.09	2.00	1	N	ND
GMS-1-A113-CF-P	N	P21-08957-42	PAS	NJDEP 15001	8/17/2021	5:51	SM 3113 B	8/18/2021	12:32	4.77	4.00	2	N	ND
GMS-1-A109-CF-P	N	P21-08957-43	PAS	NJDEP 15001	8/17/2021	5:52	SM 3113 B	8/18/2021	12:43	11.7	6.00	3	N	ND
GMS-1-A110-CF-P	N	P21-08957-44	PAS	NJDEP 15001	8/17/2021	5:53	SM 3113 B	8/18/2021	9:23	0.630	2.00	1	N	ND
GMS-1-A112-CF-P	N	P21-08957-45	PAS	NJDEP 15001	8/17/2021	5:54	SM 3113 B	8/18/2021	9:34	0.630	2.00	1	N	ND
GMS-1-A157-EC1-P	N	P21-08957-46	PAS	NJDEP 15001	8/17/2021	5:56	SM 3113 B	8/18/2021	9:38	0.290	2.00	1	N	ND
GMS-1-A157-EC2-P	N	P21-08957-47	PAS	NJDEP 15001	8/17/2021	5:57	SM 3113 B	8/18/2021	9:41	-0.01	2.00	1	N	ND
GMS-1-A157-EC3-P	N	P21-08957-48	PAS	NJDEP 15001	8/17/2021	5:58	SM 3113 B	8/18/2021	9:45	0.290	2.00	1	N	ND
GMS-1-A157-EC4-P	N	P21-08957-49	PAS	NJDEP 15001	8/17/2021	5:59	SM 3113 B	8/18/2021	9:48	0.043	2.00	1	N	ND
GMS-1-A157-EC5-P	N	P21-08957-50	PAS	NJDEP 15001	8/17/2021	6:00	SM 3113 B	8/18/2021	9:52	1.02	2.00	1	N	J
GMS-1-A157-EC6-P	N	P21-08957-51	PAS	NJDEP 15001	8/17/2021	6:01	SM 3113 B	8/18/2021	9:56	1.07	2.00	1	N	J
GMS-2-A247-TL-P	N	P21-08957-52	PAS	NJDEP 15001	8/17/2021	6:02	SM 3113 B	8/18/2021	9:59	1.16	2.00	1	N	J
GMS-2-A207-EC-P	N	P21-08957-53	PAS	NJDEP 15001	8/17/2021	6:03	SM 3113 B	8/18/2021	10:03	0.820	2.00	1	N	ND
GMS-2-A212-CF-P	N	P21-08957-54	PAS	NJDEP 15001	8/17/2021	6:04	SM 3113 B	8/18/2021	10:07	1.94	2.00	1	N	J
GMS-2-A208-CF-P	N	P21-08957-55	PAS	NJDEP 15001	8/17/2021	6:05	SM 3113 B	8/18/2021	10:27	1.70	2.00	1	N	J
GMS-2-A211-CF-P	N	P21-08957-56	PAS	NJDEP 15001	8/17/2021	6:06	SM 3113 B	8/18/2021	10:31	0.530	2.00	1	N	ND
GMS-2-A209-CF-P	N	P21-08957-57	PAS	NJDEP 15001	8/17/2021	6:07	SM 3113 B	8/18/2021	10:35	0.530	2.00	1	N	ND
GMS-2-A218-CF-P	N	P21-08957-58	PAS	NJDEP 15001	8/17/2021	6:08	SM 3113 B	8/18/2021	10:38	0.970	2.00	1	N	J
GMS-2-A219-CF-P	N	P21-08957-59	PAS	NJDEP 15001	8/17/2021	6:09	SM 3113 B	8/18/2021	10:42	2.68	2.00	1	N	ND
GMS-2-HA221-BT-P	N	P21-08957-60	PAS	NJDEP 15001	8/17/2021	6:09	SM 3113 B	8/18/2021	10:46	-0.25	2.00	1	N	ND
GMS-2-A222-CF-P	N	P21-08957-61	PAS	NJDEP 15001	8/17/2021	6:10	SM 3113 B	8/18/2021	10:49	1.02	2.00	1	N	J
GMS-2-A223-CF-P	N	P21-08957-62	PAS	NJDEP 15001	8/17/2021	6:11	SM 3113 B	8/18/2021	12:57	14.0	6.00	3	N	ND
GMS-2-A233-CF-P	N	P21-08957-63	PAS	NJDEP 15001	8/17/2021	6:13	SM 3113 B	8/18/2021	13:00	7.69	4.00	2	N	ND
<b>GMS-2-A232-CF-P</b>	<b>N</b>	<b>P21-08957-64</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/17/2021</b>	<b>6:14</b>	<b>SM 3113 B</b>	<b>8/18/2021</b>	<b>13:04</b>	<b>22.1</b>	<b>6.00</b>	<b>3</b>	<b>N</b>	
GMS-2-A230-CF-P	N	P21-08957-65	PAS	NJDEP 15001	8/17/2021	6:15	SM 3113 B	8/18/2021	11:28	0.140	2.00	1	N	ND
GMS-2-A237-CF-P	N	P21-08957-66	PAS	NJDEP 15001	8/17/2021	6:16	SM 3113 B	8/18/2021	11:32	0.970	2.00	1	N	J



## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

High School North  
90 Grovers Mill Road, Plainsboro Township, NJ 08536

Dear High School North Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, High School North will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 34 samples taken, all but 1 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action the West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
Dish Room Food Preparation Sink ID # HSN-1-DishRm-FP-P	27.0	Disconnected outlet until further notice

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.ww-p.org](http://www.ww-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : West Windsor High School North, 90 Grovers Mill Rd., Plainsboro

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank	N	P21-08958-01	PAS	NJDEP 15001	8/17/2021	4:57	SM 3113 B	8/18/2021	9:19	-0.49	2.00	1	N	ND
HSN-1-Kit-FP1-P	N	P21-08958-02	PAS	NJDEP 15001	8/17/2021	4:58	SM 3113 B	8/18/2021	9:23	0.620	2.00	1	N	ND
HSN-1-Kit-KT-P	N	P21-08958-03	PAS	NJDEP 15001	8/17/2021	4:58	SM 3113 B	8/18/2021	10:06	4.40	2.00	1	N	
HSN-1-Kit-FP2-P	N	P21-08958-04	PAS	NJDEP 15001	8/17/2021	4:59	SM 3113 B	8/18/2021	10:10	0.400	2.00	1	N	ND
HSN-1-Kit-FP3-P	N	P21-08958-05	PAS	NJDEP 15001	8/17/2021	4:59	SM 3113 B	8/18/2021	10:14	1.29	2.00	1	N	J
HSN-1-Kit-IM-P	N	P21-08958-06	PAS	NJDEP 15001	8/17/2021	5:00	SM 3113 B	8/18/2021	10:18	-0.71	2.00	1	N	ND
HSN-1-DishRm-FP-P	N	P21-08958-07	PAS	NJDEP 15001	8/17/2021	5:02	SM 3113 B	8/18/2021	13:23	27.0	4.00	2	N	
HSN-1-Concession-FP1-P	N	P21-08958-08	PAS	NJDEP 15001	8/17/2021	5:05	SM 3113 B	8/18/2021	10:26	3.29	2.00	1	N	
HSN-1-Concession-FP2-P	N	P21-08958-09	PAS	NJDEP 15001	8/17/2021	5:05	SM 3113 B	8/18/2021	10:30	5.29	2.00	1	N	
HSN-1-Concession-Hose-P	N	P21-08958-10	PAS	NJDEP 15001	8/17/2021	5:07	SM 3113 B	8/18/2021	10:34	-0.27	2.00	1	N	ND
HSN-1-Concession-IM-P	N	P21-08958-11	PAS	NJDEP 15001	8/17/2021	5:07	SM 3113 B	8/18/2021	10:38	-0.27	2.00	1	N	ND
HSN-1-TR RM-CF1-P	N	P21-08958-12	PAS	NJDEP 15001	8/17/2021	5:10	SM 3113 B	8/18/2021	10:50	1.51	2.00	1	N	J
HSN-1-TR TM-Hose-P	N	P21-08958-13	PAS	NJDEP 15001	8/17/2021	5:10	SM 3113 B	8/18/2021	10:54	5.07	2.00	1	N	
HSN-1-TR RM-CF2-P	N	P21-08958-14	PAS	NJDEP 15001	8/17/2021	5:10	SM 3113 B	8/18/2021	10:58	8.40	2.00	1	N	
HSN-1-TR TM-IM-P	N	P21-08958-15	PAS	NJDEP 15001	8/17/2021	5:10	SM 3113 B	8/18/2021	13:07	0.180	2.00	1	Y	ND
HSN-1-WLR402-BT-P	N	P21-08958-16	PAS	NJDEP 15001	8/17/2021	5:16	SM 3113 B	8/18/2021	11:02	-0.49	2.00	1	N	ND
HSN-1-Rm305-CF-P	N	P21-08958-17	PAS	NJDEP 15001	8/17/2021	5:17	SM 3113 B	8/18/2021	11:06	0.840	2.00	1	N	ND
HSN-1-MusicOffice-CF-P	N	P21-08958-18	PAS	NJDEP 15001	8/17/2021	5:19	SM 3113 B	8/18/2021	11:10	1.51	2.00	1	N	J
HSN-1-EntryH-BT-P	N	P21-08958-19	PAS	NJDEP 15001	8/17/2021	5:21	SM 3113 B	8/18/2021	11:14	-0.49	2.00	1	N	ND
HSN-1-HMO-CF-P	N	P21-08958-20	PAS	NJDEP 15001	8/17/2021	5:23	SM 3113 B	8/18/2021	11:19	-0.27	2.00	1	N	ND
HSN-1-S100-TL-P	N	P21-08958-21	PAS	NJDEP 15001	8/17/2021	5:28	SM 3113 B	8/18/2021	11:23	3.07	2.00	1	N	
HSN-1-FW104-TL-P	N	P21-08958-22	PAS	NJDEP 15001	8/17/2021	5:26	SM 3113 B	8/18/2021	11:35	-0.71	2.00	1	N	ND
HSN-1-LS105-EC1-P	N	P21-08958-23	PAS	NJDEP 15001	8/17/2021	5:30	SM 3113 B	8/18/2021	11:39	0.400	2.00	1	N	ND
HSN-1-LS105-EC2-P	N	P21-08958-24	PAS	NJDEP 15001	8/17/2021	5:30	SM 3113 B	8/18/2021	11:43	1.07	2.00	1	N	J
HSN-1-LS105-EC3-P	N	P21-08958-25	PAS	NJDEP 15001	8/17/2021	5:30	SM 3113 B	8/18/2021	11:47	-0.93	2.00	1	N	ND
HSN-1-LS105-EC4-P	N	P21-08958-26	PAS	NJDEP 15001	8/17/2021	5:30	SM 3113 B	8/18/2021	11:55	2.40	2.00	1	N	
HSN-1-Nurse-NS-P	N	P21-08958-27	PAS	NJDEP 15001	8/17/2021	5:30	SM 3113 B	8/18/2021	11:59	0.180	2.00	1	N	ND
HSN-1-Nurse ER1-NS-P	N	P21-08958-28	PAS	NJDEP 15001	8/17/2021	5:32	SM 3113 B	8/18/2021	12:03	1.73	2.00	1	N	J
HSN-1-Nurse ER2-NS-P	N	P21-08958-29	PAS	NJDEP 15001	8/17/2021	5:33	SM 3113 B	8/18/2021	12:07	2.62	2.00	1	N	
HSN-1-A109CR-TL-P	N	P21-08958-30	PAS	NJDEP 15001	8/17/2021	5:36	SM 3113 B	8/18/2021	12:11	-1.16	2.00	1	N	ND
HSN-1-CustLounge-CS-P	N	P21-08958-31	PAS	NJDEP 15001	8/17/2021	5:38	SM 3113 B	8/18/2021	12:23	-0.27	2.00	1	N	ND
HSN-2-FW211CR-TL-P	N	P21-08958-32	PAS	NJDEP 15001	8/17/2021	5:42	SM 3113 B	8/18/2021	12:27	0.840	2.00	1	N	ND
HSN-2-FWA208CR-TL-P	N	P21-08958-33	PAS	NJDEP 15001	8/17/2021	5:44	SM 3113 B	8/18/2021	12:31	-0.93	2.00	1	N	ND
HSN-2-FW219CR-TL-P	N	P21-08958-34	PAS	NJDEP 15001	8/17/2021	5:46	SM 3113 B	8/18/2021	12:35	-0.71	2.00	1	N	ND

Exceeds EPA Action Limit ( > 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

**OUTLET TYPE**

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib





## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

High School South  
342 Clarksville Road, Princeton Junction, NJ 08550

Dear High School South Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, High School South will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15  $\mu\text{g/l}$  (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 23 samples taken, all but 13 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15  $\mu\text{g/l}$  [ppb]).

The table below identifies the drinking water outlets that tested above the 15  $\mu\text{g/l}$  for lead, the actual lead level, and what temporary remedial action the West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in <math>\mu\text{g/l}</math> (ppb)</b>	<b>Remedial Action</b>
Kitchen Kettle #1 ID # HSS-1-KT1-P	28.3	Disconnected outlet until further notice
Kitchen Kettle #2 ID # HSS-1-KT2-P	112	Disconnected outlet until further notice
Kitchen Hand Sink ID # HSS-1-Kitchen-HS-P	529	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
Kitchen Food Preparation Sink #1 ID # HSS-1-Kitchen-FP1-P	56.6	Disconnected outlet until further notice
Nurse Bathroom Faucet ID # HSS-1-Nurse-BF-P	26.4	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom 91 Faucet ID # HSS-1-91-CF-P	15.3	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom 94 Faucet ID # HSS-1-94-CF-P	20.1	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom 95 Faucet ID # HSS-1-95-CF-P	46.3	Disconnected outlet until further notice
Trainer Hose Bib #1 ID # HSS-Trainer-HB1-P	63.0	Disconnected outlet until further notice
Trainer Hose Bib #2 ID # HSS-Trainer-HB2-P	95.1	Disconnected outlet until further notice
Concession Stand Faucet ID # HSS-Concession-CF-P	34.2	Disconnected outlet until further notice
2 <sup>nd</sup> Floor Science Work Room 201 Faucet ID # HSS-2-ScienceWrkRm- P-201-TL-P	47.8	Disconnected outlet until further notice
2 <sup>nd</sup> Floor Science Work Room 202 Faucet ID # HSS-2-SciencePrep-P- 202-TL-P	705	Disconnected outlet until further notice

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.



away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : WWP High School South, 346 Clarksville Road, 08550

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
HSS-1-Field Blank	N	P21-09473-01	PAS	NJDEP 15001	8/25/2021	5:30	SM 3113 B	8/26/2021	14:19	0.099	2.00	1	N	ND
HSS-1-Kitchen-KT1-P	N	P21-09473-02	PAS	NJDEP 15001	8/25/2021	5:35	SM 3113 B	8/26/2021	15:00	<b>28.3</b>	6.00	3	N	
HSS-1-Kitchen-KT2-P	N	P21-09473-03	PAS	NJDEP 15001	8/25/2021	5:37	SM 3113 B	8/26/2021	15:04	<b>112</b>	50.0	25	Y	
HSS-1-Kitchen-HS-P	N	P21-09473-04	PAS	NJDEP 15001	8/25/2021	5:40	SM 3113 B	8/26/2021	15:20	<b>529</b>	200	100	Y	
HSS-1-Kitchen-FP1-P	N	P21-09473-05	PAS	NJDEP 15001	8/25/2021	5:42	SM 3113 B	8/30/2021	4:25	<b>56.6</b>	10.0	5	N	
HSS-1-Kitchen-FP2-P	N	P21-09473-06	PAS	NJDEP 15001	8/25/2021	5:45	SM 3113 B	8/26/2021	15:28	6.12	2.00	1	N	
HSS-1-H403-BT-P	N	P21-09473-07	PAS	NJDEP 15001	8/25/2021	5:50	SM 3113 B	8/26/2021	15:32	0.720	2.00	1	N	ND
HSS-1-H700AREA-BT-P	N	P21-09473-08	PAS	NJDEP 15001	8/25/2021	5:55	SM 3113 B	8/30/2021	4:53	0.031	2.00	1	N	ND
HSS-1-FRMEZ-TL-P	N	P21-09473-09	PAS	NJDEP 15001	8/25/2021	6:00	SM 3113 B	8/30/2021	4:57	1.03	2.00	1	N	J
HSS-1-Nurse-BF-P	N	P21-09473-10	PAS	NJDEP 15001	8/25/2021	6:02	SM 3113 B	8/30/2021	5:01	<b>26.4</b>	6.00	3	N	
HSS-1-Nurse-NS1-P	N	P21-09473-11	PAS	NJDEP 15001	8/25/2021	6:03	SM 3113 B	8/30/2021	5:05	1.29	2.00	1	N	J
HSS-1-Nurse-NS2-P	N	P21-09473-12	PAS	NJDEP 15001	8/25/2021	6:04	SM 3113 B	8/30/2021	5:09	9.81	2.00	1	N	
HSS-1-Commons 2-BT-P	N	P21-09473-13	PAS	NJDEP 15001	8/25/2021	6:06	SM 3113 B	8/30/2021	5:13	0.031	2.00	1	N	ND
HSS-1-91-CF-P	N	P21-09473-14	PAS	NJDEP 15001	8/25/2021	6:07	SM 3113 B	8/30/2021	5:17	<b>15.3</b>	2.00	1	N	
HSS-1-94-CF-P	N	P21-09473-15	PAS	NJDEP 15001	8/25/2021	6:09	SM 3113 B	8/30/2021	5:21	<b>20.1</b>	4.00	2	N	
HSS-1-95-CF-P	N	P21-09473-16	PAS	NJDEP 15001	8/25/2021	6:11	SM 3113 B	8/30/2021	5:46	<b>46.3</b>	8.00	4	N	
HSS-TrainerWetRm-IM-P	N	P21-09473-17	PAS	NJDEP 15001	8/25/2021	6:25	SM 3113 B	8/30/2021	5:51	-0.22	2.00	1	N	ND
HSS-Trainer-HB1-P	N	P21-09473-18	PAS	NJDEP 15001	8/25/2021	6:27	SM 3113 B	8/30/2021	5:55	<b>63.0</b>	20.0	10	N	
HSS-Trainer-HB2-P	N	P21-09473-19	PAS	NJDEP 15001	8/25/2021	6:30	SM 3113 B	8/30/2021	6:41	<b>95.1</b>	18.0	9	N	
HSS-Concession-CF-P	N	P21-09473-20	PAS	NJDEP 15001	8/25/2021	6:33	SM 3113 B	8/30/2021	6:03	<b>34.2</b>	8.00	4	N	
HSS-2-ScienceWrkRm-P-201-TL-P	N	P21-09473-21	PAS	NJDEP 15001	8/25/2021	6:43	SM 3113 B	8/30/2021	6:45	<b>47.8</b>	10.0	5	N	
HSS-2-SciencePrep-P-202-TL-P	N	P21-09473-22	PAS	NJDEP 15001	8/25/2021	6:45	SM 3113 B	8/30/2021	6:49	<b>705</b>	200	100	Y	
HSS-2-SciencePrep-P-204-TL-P	N	P21-09473-23	PAS	NJDEP 15001	8/25/2021	6:48	SM 3113 B	8/30/2021	6:53	8.56	2.00	1	N	

**Exceeds EPA Action Limit ( > 15.5ppb)**

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)primary / (F)lush

**OUTLET TYPE**

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib



## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

Maurice Hawk Elementary School  
305 Clarksville Rd, Princeton Junction, NJ 08550

Dear Maurice Hawk Elementary School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Maurice Hawk Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 60 samples taken, all but 3 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action the West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
1 <sup>st</sup> Floor Classroom Faucet ID # MHES-1-210-CF-P	28.4	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom Faucet ID # MHES-1-211-CF-P	273	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom Faucet ID # MHES-1-223-CF-P	17.6	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

## Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

## Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

## For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Maurice Hawk Elementary School, 305 Clarksville Rd.

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank	N	P21-08571-01	PAS	NJDEP 15001	8/10/2021	4:53	SM 3113 B	8/11/2021	8:04	0.150	2.00	1	N	ND
MHES-1-410-CF-P	N	P21-08571-02	PAS	NJDEP 15001	8/10/2021	4:54	SM 3113 B	8/11/2021	8:08	1.70	2.00	1	N	J
MHES-1-407-CF-P	N	P21-08571-03	PAS	NJDEP 15001	8/10/2021	4:55	SM 3113 B	8/11/2021	8:31	0.590	2.00	1	N	ND
MHES-1-5413-BT-P	N	P21-08571-04	PAS	NJDEP 15001	8/10/2021	4:56	SM 3113 B	8/11/2021	8:35	-0.07	2.00	1	N	ND
MHES-1-405-CF-P	N	P21-08571-05	PAS	NJDEP 15001	8/10/2021	4:57	SM 3113 B	8/11/2021	8:39	1.48	2.00	1	N	J
MHES-1-404-CF-P	N	P21-08571-06	PAS	NJDEP 15001	8/10/2021	4:58	SM 3113 B	8/11/2021	8:43	1.04	2.00	1	N	J
MHES-1-403-CF-P	N	P21-08571-07	PAS	NJDEP 15001	8/10/2021	4:59	SM 3113 B	8/11/2021	8:47	1.48	2.00	1	N	J
MHES-1-412-CF-P	N	P21-08571-08	PAS	NJDEP 15001	8/10/2021	5:01	SM 3113 B	8/11/2021	8:51	0.810	2.00	1	N	ND
MHES-1-415-CF-P	N	P21-08571-09	PAS	NJDEP 15001	8/10/2021	5:02	SM 3113 B	8/11/2021	8:55	0.590	2.00	1	N	ND
MHES-1-414-CF-P	N	P21-08571-10	PAS	NJDEP 15001	8/10/2021	5:03	SM 3113 B	8/11/2021	8:59	1.26	2.00	1	N	J
MHES-1-416-CF-P	N	P21-08571-11	PAS	NJDEP 15001	8/10/2021	5:04	SM 3113 B	8/11/2021	9:03	0.810	2.00	1	N	ND
MHES-1-418-CF-P	N	P21-08571-12	PAS	NJDEP 15001	8/10/2021	5:05	SM 3113 B	8/11/2021	9:15	0.810	2.00	1	N	ND
MHES-1-422-TL-P	N	P21-08571-13	PAS	NJDEP 15001	8/10/2021	5:06	SM 3113 B	8/11/2021	9:20	1.04	2.00	1	N	J
MHES-1-430-CF-P	N	P21-08571-14	PAS	NJDEP 15001	8/10/2021	5:07	SM 3113 B	8/11/2021	9:24	1.48	2.00	1	N	J
MHES-1-431-CF-P	N	P21-08571-15	PAS	NJDEP 15001	8/10/2021	5:08	SM 3113 B	8/11/2021	9:28	0.810	2.00	1	N	ND
MHES-1-506-TL-P	N	P21-08571-16	PAS	NJDEP 15001	8/10/2021	5:10	SM 3113 B	8/11/2021	9:32	0.590	2.00	1	N	ND
MHES-1-H Audio Visual-BT-P	N	P21-08571-17	PAS	NJDEP 15001	8/10/2021	5:11	SM 3113 B	8/11/2021	9:36	0.150	2.00	1	N	ND
MHES-1-Nurse-NS-P	N	P21-08571-18	PAS	NJDEP 15001	8/10/2021	5:12	SM 3113 B	8/11/2021	9:40	0.810	2.00	1	N	ND
MHES-1-132-CF-P	N	P21-08571-19	PAS	NJDEP 15001	8/10/2021	5:13	SM 3113 B	8/11/2021	9:44	6.35	2.00	1	N	ND
MHES-1-129-CF-P	N	P21-08571-20	PAS	NJDEP 15001	8/10/2021	5:14	SM 3113 B	8/11/2021	9:48	13.9	2.00	1	N	ND
MHES-1-127-CF-P	N	P21-08571-21	PAS	NJDEP 15001	8/10/2021	5:15	SM 3113 B	8/11/2021	10:01	6.58	2.00	1	N	ND
MHES-1-130-CF-P	N	P21-08571-22	PAS	NJDEP 15001	8/10/2021	5:16	SM 3113 B	8/11/2021	10:17	8.35	2.00	1	N	ND
MHES-1-128-CF-P	N	P21-08571-23	PAS	NJDEP 15001	8/10/2021	5:17	SM 3113 B	8/11/2021	10:20	2.81	2.00	1	N	ND
MHES-1-121-CF-P	N	P21-08571-24	PAS	NJDEP 15001	8/10/2021	5:18	SM 3113 B	8/11/2021	10:24	2.59	2.00	1	N	ND
MHES-1-119-CF-P	N	P21-08571-25	PAS	NJDEP 15001	8/10/2021	5:19	SM 3113 B	8/11/2021	10:28	3.92	2.00	1	N	ND
MHES-1-136-CF-P	N	P21-08571-26	PAS	NJDEP 15001	8/10/2021	5:20	SM 3113 B	8/11/2021	10:32	7.24	2.00	1	N	ND
MHES-1-MO Hall-TL-P	N	P21-08571-27	PAS	NJDEP 15001	8/10/2021	5:21	SM 3113 B	8/11/2021	11:00	0.590	2.00	1	N	ND
MHES-1-162-Faculty-TL-P	N	P21-08571-28	PAS	NJDEP 15001	8/10/2021	5:26	SM 3113 B	8/11/2021	11:04	1.04	2.00	1	N	J
MHES-1-160-CF-P	N	P21-08571-29	PAS	NJDEP 15001	8/10/2021	5:27	SM 3113 B	8/11/2021	12:15	7.91	2.00	1	Y	ND
MHES-1-135-CF-P	N	P21-08571-30	PAS	NJDEP 15001	8/10/2021	5:28	SM 3113 B	8/11/2021	11:08	3.03	2.00	1	N	ND
MHES-1-150-TL-P	N	P21-08571-31	PAS	NJDEP 15001	8/10/2021	5:29	SM 3113 B	8/11/2021	11:12	5.02	2.00	1	N	ND
MHES-1-H150-BT-P	N	P21-08571-32	PAS	NJDEP 15001	8/10/2021	5:30	SM 3113 B	8/11/2021	11:16	-0.07	2.00	1	N	ND
MHES-1-Kitchen-FP1-P	N	P21-08571-33	PAS	NJDEP 15001	8/10/2021	5:32	SM 3113 B	8/11/2021	11:20	1.92	2.00	1	N	J
MHES-1-Kitchen-FP2-P	N	P21-08571-34	PAS	NJDEP 15001	8/10/2021	5:33	SM 3113 B	8/11/2021	11:24	0.590	2.00	1	N	ND
MHES-1-Kitchen-FP3-P	N	P21-08571-35	PAS	NJDEP 15001	8/10/2021	5:34	SM 3113 B	8/11/2021	11:47	0.590	2.00	1	N	ND
MHES-1-203-CF-P	N	P21-08571-36	PAS	NJDEP 15001	8/10/2021	5:35	SM 3113 B	8/11/2021	11:51	3.03	2.00	1	N	ND
MHES-1-202-CF-P	N	P21-08571-37	PAS	NJDEP 15001	8/10/2021	5:36	SM 3113 B	8/11/2021	11:55	1.04	2.00	1	N	J
MHES-1-208-CF-P	N	P21-08571-38	PAS	NJDEP 15001	8/10/2021	5:37	SM 3113 B	8/11/2021	11:59	1.26	2.00	1	N	J
MHES-1-207-CF-P	N	P21-08571-39	PAS	NJDEP 15001	8/10/2021	5:38	SM 3113 B	8/11/2021	12:03	4.80	2.00	1	N	ND
MHES-1-210-CF-P	N	P21-08571-40	PAS	NJDEP 15001	8/10/2021	5:39	SM 3113 B	8/11/2021	14:35	28.4	6.00	3	Y	ND
MHES-1-211-CF-P	N	P21-08571-41	PAS	NJDEP 15001	8/10/2021	5:40	SM 3113 B	8/11/2021	14:38	273	100	50	Y	ND
MHES-1-214-CF-P	N	P21-08571-42	PAS	NJDEP 15001	8/10/2021	5:41	SM 3113 B	8/11/2021	12:51	5.91	2.00	1	N	ND
MHES-1-216-CF-P	N	P21-08571-43	PAS	NJDEP 15001	8/10/2021	5:42	SM 3113 B	8/11/2021	12:55	3.70	2.00	1	N	ND
MHES-1-218-CF-P	N	P21-08571-44	PAS	NJDEP 15001	8/10/2021	5:43	SM 3113 B	8/11/2021	12:59	2.59	2.00	1	N	ND
MHES-1-223-CF-P	N	P21-08571-45	PAS	NJDEP 15001	8/10/2021	5:44	SM 3113 B	8/11/2021	14:42	17.6	4.00	2	Y	ND
MHES-1-225-CF-P	N	P21-08571-46	PAS	NJDEP 15001	8/10/2021	5:45	SM 3113 B	8/11/2021	13:03	1.04	2.00	1	N	J
MHES-1-222-CF1-P	N	P21-08571-47	PAS	NJDEP 15001	8/10/2021	5:45	SM 3113 B	8/11/2021	13:16	2.59	2.00	1	N	ND
MHES-1-222-CF2-P	N	P21-08571-48	PAS	NJDEP 15001	8/10/2021	5:46	SM 3113 B	8/11/2021	13:20	7.68	2.00	1	N	ND
MHES-1-227-CF-P	N	P21-08571-49	PAS	NJDEP 15001	8/10/2021	5:47	SM 3113 B	8/11/2021	13:24	1.70	2.00	1	N	J
MHES-1-224-CF-P	N	P21-08571-50	PAS	NJDEP 15001	8/10/2021	5:48	SM 3113 B	8/11/2021	13:28	1.70	2.00	1	N	J
MHES-1-304-CF-P	N	P21-08571-51	PAS	NJDEP 15001	8/10/2021	5:50	SM 3113 B	8/11/2021	13:32	1.04	2.00	1	N	J
MHES-1-311-CF-P	N	P21-08571-52	PAS	NJDEP 15001	8/10/2021	5:51	SM 3113 B	8/11/2021	13:36	1.92	2.00	1	N	J
MHES-1-306-CF-P	N	P21-08571-53	PAS	NJDEP 15001	8/10/2021	5:51	SM 3113 B	8/11/2021	13:40	1.04	2.00	1	N	J
MHES-1-313-CF-P	N	P21-08571-54	PAS	NJDEP 15001	8/10/2021	5:52	SM 3113 B	8/11/2021	13:44	1.92	2.00	1	N	J
MHES-1-308-CF-P	N	P21-08571-55	PAS	NJDEP 15001	8/10/2021	5:53	SM 3113 B	8/11/2021	13:48	3.92	2.00	1	N	ND
MHES-1-315-CF-P	N	P21-08571-56	PAS	NJDEP 15001	8/10/2021	5:53	SM 3113 B	8/11/2021	14:00	1.48	2.00	1	N	J
MHES-1-310-CF-P	N	P21-08571-57	PAS	NJDEP 15001	8/10/2021	5:54	SM 3113 B	8/11/2021	14:04	0.810	2.00	1	N	ND
MHES-1-317-CF-P	N	P21-08571-58	PAS	NJDEP 15001	8/10/2021	5:55	SM 3113 B	8/11/2021	14:08	1.70	2.00	1	N	J
MHES-1-402-CF-P	N	P21-08571-59	PAS	NJDEP 15001	8/10/2021	5:56	SM 3113 B	8/11/2021	14:12	0.810	2.00	1	N	ND
MHES-1-401-CF-P	N	P21-08571-60	PAS	NJDEP 15001	8/10/2021	5:57	SM 3113 B	8/11/2021	14:16	0.590	2.00	1	N	ND



## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

Millstone River School  
75 Grovers Mill Rd, Plainsboro Township, NJ 08536

Dear Millstone River School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Millstone River School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15  $\mu\text{g/l}$  (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 78 samples taken, all but 2 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15  $\mu\text{g/l}$  [ppb]).

The table below identifies the drinking water outlets that tested above the 15  $\mu\text{g/l}$  for lead, the actual lead level, and what temporary remedial action West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in <math>\mu\text{g/l}</math> (ppb)</b>	<b>Remedial Action</b>
Kitchen Kettle Faucet ID # MRS-1-Kit-KT-P	41.7	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom Faucet ID# MRS-1-B110-CF-P	21.3	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

## Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

## Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

## For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.ww-p.org](http://www.ww-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds



**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Millstone River School, 75 Grovers Mill Road

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank	N	P21-08822-01	PAS	NJDEP 15001	8/13/2021	4:58	SM 3113 B	8/16/2021	7:22	0.090	2.00	1	N	ND
MRS-1-D148-CF-P	N	P21-08822-02	PAS	NJDEP 15001	8/13/2021	4:58	SM 3113 B	8/16/2021	7:26	1.29	2.00	1	N	J
MRS-1-149D-TL-P	N	P21-08822-03	PAS	NJDEP 15001	8/13/2021	5:02	SM 3113 B	8/16/2021	7:57	0.330	2.00	1	N	ND
MRS-1-HD143-BT1-P	N	P21-08822-04	PAS	NJDEP 15001	8/13/2021	5:06	SM 3113 B	8/16/2021	8:01	0.090	2.00	1	N	ND
MRS-1-Kit-FP1-P	N	P21-08822-05	PAS	NJDEP 15001	8/13/2021	5:09	SM 3113 B	8/16/2021	8:05	1.29	2.00	1	N	J
MRS-1-Kit-FP2-P	N	P21-08822-06	PAS	NJDEP 15001	8/13/2021	5:10	SM 3113 B	8/16/2021	8:09	1.05	2.00	1	N	J
MRS-1-Kit-FP3-P	N	P21-08822-07	PAS	NJDEP 15001	8/13/2021	5:11	SM 3113 B	8/16/2021	8:13	3.21	2.00	1	N	
MRS-1-Kit-FP4-P	N	P21-08822-08	PAS	NJDEP 15001	8/13/2021	5:12	SM 3113 B	8/16/2021	8:17	2.73	2.00	1	N	
MRS-1-Kit-KT-P	N	P21-08822-09	PAS	NJDEP 15001	8/13/2021	5:13	SM 3113 B	8/16/2021	11:02	41.7	20.0	10	N	
MRS-1-Teacher-TL-P	N	P21-08822-10	PAS	NJDEP 15001	8/13/2021	5:14	SM 3113 B	8/16/2021	8:25	0.570	2.00	1	N	ND
MRS-1-D103-CF-P	N	P21-08822-11	PAS	NJDEP 15001	8/13/2021	5:15	SM 3113 B	8/16/2021	8:28	0.810	2.00	1	N	ND
MRS-1-Nurse-NS-P	N	P21-08822-12	PAS	NJDEP 15001	8/13/2021	5:16	SM 3113 B	8/16/2021	8:41	0.090	2.00	1	N	ND
MRS-1-MO-TL-P	N	P21-08822-13	PAS	NJDEP 15001	8/13/2021	5:20	SM 3113 B	8/16/2021	8:45	0.330	2.00	1	N	ND
MRS-1-C132-TL-P	N	P21-08822-14	PAS	NJDEP 15001	8/13/2021	5:21	SM 3113 B	8/16/2021	8:49	0.330	2.00	1	N	ND
MRS-1-C132-BT-P	N	P21-08822-15	PAS	NJDEP 15001	8/13/2021	5:22	SM 3113 B	8/16/2021	8:53	0.090	2.00	1	N	ND
MRS-1-C135-BT-P	N	P21-08822-16	PAS	NJDEP 15001	8/13/2021	5:23	SM 3113 B	8/16/2021	8:57	0.090	2.00	1	N	ND
MRS-1-A157-CF-P	N	P21-08822-17	PAS	NJDEP 15001	8/13/2021	5:26	SM 3113 B	8/16/2021	9:01	0.330	2.00	1	N	ND
MRS-1-A156-CF-P	N	P21-08822-18	PAS	NJDEP 15001	8/13/2021	5:27	SM 3113 B	8/16/2021	9:05	0.810	2.00	1	N	ND
MRS-1-A155-CF-P	N	P21-08822-19	PAS	NJDEP 15001	8/13/2021	5:28	SM 3113 B	8/16/2021	9:09	0.330	2.00	1	N	ND
MRS-1-A154-CF-P	N	P21-08822-20	PAS	NJDEP 15001	8/13/2021	5:29	SM 3113 B	8/16/2021	9:14	1.05	2.00	1	N	J
MRS-1-A153-CF-P	N	P21-08822-21	PAS	NJDEP 15001	8/13/2021	5:30	SM 3113 B	8/16/2021	9:26	13.8	2.00	1	N	
MRS-1-A152-CF-P	N	P21-08822-22	PAS	NJDEP 15001	8/13/2021	5:31	SM 3113 B	8/16/2021	9:42	2.49	2.00	1	N	
MRS-1-A149-CF-P	N	P21-08822-23	PAS	NJDEP 15001	8/13/2021	5:32	SM 3113 B	8/16/2021	9:46	1.05	2.00	1	N	J
MRS-1-A146-CF-P	N	P21-08822-24	PAS	NJDEP 15001	8/13/2021	5:33	SM 3113 B	8/16/2021	9:50	6.10	2.00	1	N	
MRS-1-A148-CF-P	N	P21-08822-25	PAS	NJDEP 15001	8/13/2021	5:33	SM 3113 B	8/16/2021	9:54	0.810	2.00	1	N	ND
MRS-1-A145-CF-P	N	P21-08822-26	PAS	NJDEP 15001	8/13/2021	5:34	SM 3113 B	8/16/2021	9:58	1.29	2.00	1	N	J
MRS-1-A147-CF-P	N	P21-08822-27	PAS	NJDEP 15001	8/13/2021	5:35	SM 3113 B	8/16/2021	10:10	4.17	2.00	1	N	
MRS-1-A141-CF-P	N	P21-08822-28	PAS	NJDEP 15001	8/13/2021	5:36	SM 3113 B	8/16/2021	10:14	1.29	2.00	1	N	J
MRS-1-A140-CF-P	N	P21-08822-29	PAS	NJDEP 15001	8/13/2021	5:37	SM 3113 B	8/16/2021	10:18	0.330	2.00	1	N	ND
MRS-1-A139-CF-P	N	P21-08822-30	PAS	NJDEP 15001	8/13/2021	5:37	SM 3113 B	8/16/2021	10:22	0.330	2.00	1	N	ND
MRS-1-A118-CF-P	N	P21-08822-31	PAS	NJDEP 15001	8/13/2021	5:39	SM 3113 B	8/16/2021	10:26	0.330	2.00	1	N	ND
MRS-1-A117-CF-P	N	P21-08822-32	PAS	NJDEP 15001	8/13/2021	5:40	SM 3113 B	8/16/2021	10:29	0.810	2.00	1	N	ND
MRS-1-A116-CF-P	N	P21-08822-33	PAS	NJDEP 15001	8/13/2021	5:41	SM 3113 B	8/16/2021	10:33	5.38	2.00	1	N	
MRS-1-A110-CF-P	N	P21-08822-34	PAS	NJDEP 15001	8/13/2021	5:42	SM 3113 B	8/16/2021	10:37	2.01	2.00	1	N	
MRS-1-A112-CF-P	N	P21-08822-35	PAS	NJDEP 15001	8/13/2021	5:42	SM 3113 B	8/16/2021	10:42	2.49	2.00	1	N	
MRS-1-A109-CF-P	N	P21-08822-36	PAS	NJDEP 15001	8/13/2021	5:43	SM 3113 B	8/16/2021	12:57	5.91	2.00	1	Y	
MRS-1-A111-CF-P	N	P21-08822-37	PAS	NJDEP 15001	8/13/2021	5:44	SM 3113 B	8/16/2021	11:06	0.570	2.00	1	N	ND
MRS-1-A108-CF-P	N	P21-08822-38	PAS	NJDEP 15001	8/13/2021	5:45	SM 3113 B	8/16/2021	11:10	4.17	2.00	1	N	
MRS-1-A105-CF-P	N	P21-08822-39	PAS	NJDEP 15001	8/13/2021	5:46	SM 3113 B	8/16/2021	11:14	0.570	2.00	1	N	ND
MRS-1-A104-CF-P	N	P21-08822-40	PAS	NJDEP 15001	8/13/2021	5:47	SM 3113 B	8/16/2021	11:18	0.330	2.00	1	N	ND
MRS-1-A103-CF-P	N	P21-08822-41	PAS	NJDEP 15001	8/13/2021	5:47	SM 3113 B	8/16/2021	8:22	0.460	2.00	1	N	ND
MRS-1-A102-CF-P	N	P21-08822-42	PAS	NJDEP 15001	8/13/2021	5:48	SM 3113 B	8/16/2021	8:38	-0.25	2.00	1	N	ND
MRS-1-A101-CF-P	N	P21-08822-43	PAS	NJDEP 15001	8/13/2021	5:49	SM 3113 B	8/16/2021	8:50	-0.25	2.00	1	N	ND
MRS-1-HA100-BT-P	N	P21-08822-44	PAS	NJDEP 15001	8/13/2021	5:50	SM 3113 B	8/16/2021	8:54	-0.49	2.00	1	N	ND
MRS-1-A100-CF-P	N	P21-08822-45	PAS	NJDEP 15001	8/13/2021	5:50	SM 3113 B	8/16/2021	8:58	0.220	2.00	1	N	ND
MRS-1-A125-CF-P	N	P21-08822-46	PAS	NJDEP 15001	8/13/2021	5:51	SM 3113 B	8/16/2021	9:02	-0.49	2.00	1	N	ND
MRS-1-C105-CF-P	N	P21-08822-47	PAS	NJDEP 15001	8/13/2021	5:54	SM 3113 B	8/16/2021	9:05	-0.01	2.00	1	N	ND
MRS-1-B125-CF-P	N	P21-08822-48	PAS	NJDEP 15001	8/13/2021	5:55	SM 3113 B	8/16/2021	9:09	-0.49	2.00	1	N	ND
MRS-1-B100-CF-P	N	P21-08822-49	PAS	NJDEP 15001	8/13/2021	5:56	SM 3113 B	8/16/2021	9:14	-0.25	2.00	1	N	ND
MRS-1-HB100-BT-P	N	P21-08822-50	PAS	NJDEP 15001	8/13/2021	5:57	SM 3113 B	8/16/2021	9:18	-0.96	2.00	1	N	ND
MRS-1-B101-CF-P	N	P21-08822-51	PAS	NJDEP 15001	8/13/2021	5:58	SM 3113 B	8/16/2021	9:22	-0.25	2.00	1	N	ND
MRS-1-B102-CF-P	N	P21-08822-52	PAS	NJDEP 15001	8/13/2021	5:59	SM 3113 B	8/16/2021	9:41	1.17	2.00	1	N	J
MRS-1-B103-CF-P	N	P21-08822-53	PAS	NJDEP 15001	8/13/2021	6:00	SM 3113 B	8/16/2021	9:45	0.220	2.00	1	N	ND
MRS-1-B104-CF-P	N	P21-08822-54	PAS	NJDEP 15001	8/13/2021	6:01	SM 3113 B	8/16/2021	9:49	0.700	2.00	1	N	ND
MRS-1-B105-CF-P	N	P21-08822-55	PAS	NJDEP 15001	8/13/2021	6:01	SM 3113 B	8/16/2021	9:53	3.78	2.00	1	N	
MRS-1-B108-CF-P	N	P21-08822-56	PAS	NJDEP 15001	8/13/2021	6:02	SM 3113 B	8/16/2021	9:57	0.700	2.00	1	N	ND
MRS-1-B111-CF-P	N	P21-08822-57	PAS	NJDEP 15001	8/13/2021	6:03	SM 3113 B	8/16/2021	10:02	0.700	2.00	1	N	ND
MRS-1-B112-CF-P	N	P21-08822-58	PAS	NJDEP 15001	8/13/2021	6:05	SM 3113 B	8/16/2021	10:06	0.460	2.00	1	N	ND
MRS-1-B110-CF-P	N	P21-08822-59	PAS	NJDEP 15001	8/13/2021	6:06	SM 3113 B	8/16/2021	12:03	21.3	4.00	2	N	
MRS-1-B116-CF-P	N	P21-08822-60	PAS	NJDEP 15001	8/13/2021	6:06	SM 3113 B	8/16/2021	10:14	0.930	2.00	1	N	J
MRS-1-B117-CF-P	N	P21-08822-61	PAS	NJDEP 15001	8/13/2021	6:07	SM 3113 B	8/16/2021	10:30	2.12	2.00	1	N	
MRS-1-B118-CF-P	N	P21-08822-62	PAS	NJDEP 15001	8/13/2021	6:08	SM 3113 B	8/16/2021	10:42	0.930	2.00	1	N	J
MRS-1-B121-CF-P	N	P21-08822-63	PAS	NJDEP 15001	8/13/2021	6:09	SM 3113 B	8/16/2021	10:46	-0.01	2.00	1	N	ND
MRS-1-B157-CF-P	N	P21-08822-64	PAS	NJDEP 15001	8/13/2021	6:11	SM 3113 B	8/16/2021	10:50	1.88	2.00	1	N	J
MRS-1-B156-CF-P	N	P21-08822-65	PAS	NJDEP 15001	8/13/2021	6:12	SM 3113 B	8/16/2021	10:54	0.460	2.00	1	N	ND
MRS-1-B155-CF-P	N	P21-08822-66	PAS	NJDEP 15001	8/13/2021	6:13	SM 3113 B	8/16/2021	10:58	0.700	2.00	1	N	ND
MRS-1-B154-CF-P	N	P21-08822-67	PAS	NJDEP 15001	8/13/2021	6:14	SM 3113 B	8/16/2021	11:10	0.700	2.00	1	N	ND
MRS-1-B153-CF-P	N	P21-08822-68	PAS	NJDEP 15001	8/13/2021	6:15	SM 3113 B	8/16/2021	11:14	1.17	2.00	1	N	J
MRS-1-B152-CF-P	N	P21-08822-69	PAS	NJDEP 15001	8/13/2021	6:16	SM 3113 B	8/16/2021	11:18	0.700	2.00	1	N	ND



**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
 Project ID : Millstone River School, 75 Grovers Mill Road

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
MRS-1-B149-CF-P	N	P21-08822-70	PAS	NJDEP 15001	8/13/2021	6:17	SM 3113 B	8/16/2021	11:22	0.220	2.00	1	N	ND
MRS-1-B146-CF-P	N	P21-08822-71	PAS	NJDEP 15001	8/13/2021	6:18	SM 3113 B	8/16/2021	11:26	0.220	2.00	1	N	ND
MRS-1-B148-CF1-P	N	P21-08822-72	PAS	NJDEP 15001	8/13/2021	6:19	SM 3113 B	8/16/2021	11:30	-0.01	2.00	1	N	ND
MRS-1-B148-CF2-P	N	P21-08822-73	PAS	NJDEP 15001	8/13/2021	6:20	SM 3113 B	8/16/2021	11:34	0.700	2.00	1	N	ND
MRS-1-B145-CF-P	N	P21-08822-74	PAS	NJDEP 15001	8/13/2021	6:21	SM 3113 B	8/16/2021	11:38	2.59	2.00	1	N	ND
MRS-1-B147-CF-P	N	P21-08822-75	PAS	NJDEP 15001	8/13/2021	6:22	SM 3113 B	8/16/2021	12:11	0.700	2.00	1	N	ND
MRS-1-B141-CF-P	N	P21-08822-76	PAS	NJDEP 15001	8/13/2021	6:23	SM 3113 B	8/16/2021	13:13	8.04	2.00	1	Y	
MRS-1-B140-CF-P	N	P21-08822-77	PAS	NJDEP 15001	8/13/2021	6:24	SM 3113 B	8/16/2021	12:15	0.700	2.00	1	N	ND
MRS-1-B139-CF-P	N	P21-08822-78	PAS	NJDEP 15001	8/13/2021	6:25	SM 3113 B	8/16/2021	13:17	7.56	2.00	1	Y	



## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

Town Center Elementary School  
700 Wyndhurst Dr, Plainsboro Township, NJ 08536

Dear Town Center Elementary School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Town Center will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15  $\mu\text{g/l}$  (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 61 samples taken, all but 3 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15  $\mu\text{g/l}$  [ppb]).

The table below identifies the drinking water outlets that tested above the 15  $\mu\text{g/l}$  for lead, the actual lead level, and what temporary remedial action the West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in <math>\mu\text{g/l}</math> (ppb)</b>	<b>Remedial Action</b>
Kitchen Kettle Faucet ID # TCE-1-Kit-KT-P	177	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom Faucet ID# TCE-1-B126-CF-P	16.3	Disconnected outlet until further notice
2 <sup>nd</sup> Floor Classroom Faucet ID # TCE-2-B205-CF-P	23.2	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

## Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

## How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

## Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

## For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : Town Center Elementary - 700 Wyndhurst Dr.

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
Field Blank	N	P21-08378-01	PAS	NJDEP 15001	8/6/2021	4:52	SM 3113 B	8/10/2021	7:38	0.670	2.00	1	N	ND
TCE-1-Cust LOU CF-P	N	P21-08378-02	PAS	NJDEP 15001	8/6/2021	4:53	SM 3113 B	8/10/2021	8:00	-0.21	2.00	1	N	ND
TCE-1-Kit-1M-P	N	P21-08378-03	PAS	NJDEP 15001	8/6/2021	4:54	SM 3113 B	8/10/2021	8:15	0.0055	2.00	1	N	ND
<b>TCE-1-Kit-KT-P</b>	<b>N</b>	<b>P21-08378-04</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/6/2021</b>	<b>4:57</b>	<b>SM 3113 B</b>	<b>8/10/2021</b>	<b>10:06</b>	<b>177</b>	<b>100</b>	<b>50</b>	<b>Y</b>	
TCE-1-Kit-FP1-P	N	P21-08378-05	PAS	NJDEP 15001	8/6/2021	4:58	SM 3113 B	8/10/2021	8:23	4.41	2.00	1	N	
TCE-1-Kit-FP2-P	N	P21-08378-06	PAS	NJDEP 15001	8/6/2021	4:58	SM 3113 B	8/10/2021	8:27	1.55	2.00	1	N	J
TCE-1-Kit-FP3-P	N	P21-08378-07	PAS	NJDEP 15001	8/6/2021	4:59	SM 3113 B	8/10/2021	8:39	0.450	2.00	1	N	ND
TCE-1-HA76-BT-P	N	P21-08378-08	PAS	NJDEP 15001	8/6/2021	5:01	SM 3113 B	8/10/2021	8:43	0.230	2.00	1	N	ND
TCE-1-A43-NS-P	N	P21-08378-09	PAS	NJDEP 15001	8/6/2021	5:03	SM 3113 B	8/10/2021	8:47	5.52	2.00	1	N	
TCE-1-A40-NS-P	N	P21-08378-10	PAS	NJDEP 15001	8/6/2021	5:03	SM 3113 B	8/10/2021	8:52	0.890	2.00	1	N	ND
TCE-1-A13-TL1-P	N	P21-08378-11	PAS	NJDEP 15001	8/6/2021	5:04	SM 3113 B	8/10/2021	8:56	9.26	2.00	1	N	
TCE-1-A13-TL2-P	N	P21-08378-12	PAS	NJDEP 15001	8/6/2021	5:05	SM 3113 B	8/10/2021	9:00	1.77	2.00	1	N	J
TCE-1-A32-TL-P	N	P21-08378-13	PAS	NJDEP 15001	8/6/2021	5:06	SM 3113 B	8/10/2021	9:04	0.890	2.00	1	N	ND
TCE-1-A90-TL-P	N	P21-08378-14	PAS	NJDEP 15001	8/6/2021	5:08	SM 3113 B	8/10/2021	9:08	0.0055	2.00	1	N	ND
TCE-1-B100-CF-P	N	P21-08378-15	PAS	NJDEP 15001	8/6/2021	5:10	SM 3113 B	8/10/2021	9:12	3.31	2.00	1	N	
TCE-1-B101-CF-P	N	P21-08378-16	PAS	NJDEP 15001	8/6/2021	5:12	SM 3113 B	8/10/2021	9:24	5.07	2.00	1	N	
TCE-1-B102-CF-P	N	P21-08378-17	PAS	NJDEP 15001	8/6/2021	5:13	SM 3113 B	8/10/2021	9:29	0.670	2.00	1	N	ND
TCE-1-B104-CF-P	N	P21-08378-18	PAS	NJDEP 15001	8/6/2021	5:14	SM 3113 B	8/10/2021	9:33	0.450	2.00	1	N	ND
TCE-1-B103-CF-P	N	P21-08378-19	PAS	NJDEP 15001	8/6/2021	5:14	SM 3113 B	8/10/2021	9:37	0.230	2.00	1	N	ND
TCE-1-B105-CF-P	N	P21-08378-20	PAS	NJDEP 15001	8/6/2021	5:15	SM 3113 B	8/10/2021	9:41	5.74	2.00	1	N	
TCE-1-B107-CF-P	N	P21-08378-21	PAS	NJDEP 15001	8/6/2021	5:16	SM 3113 B	8/10/2021	10:10	1.77	2.00	1	N	J
TCE-1-B106-CF-P	N	P21-08378-22	PAS	NJDEP 15001	8/6/2021	5:17	SM 3113 B	8/10/2021	10:25	2.21	2.00	1	N	
TCE-1-H77-BT-P	N	P21-08378-23	PAS	NJDEP 15001	8/6/2021	5:18	SM 3113 B	8/10/2021	10:29	0.0055	2.00	1	N	ND
TCE-1-A50-CF-P	N	P21-08378-24	PAS	NJDEP 15001	8/6/2021	5:19	SM 3113 B	8/10/2021	10:33	2.43	2.00	1	N	
TCE-1-B120-CF-P	N	P21-08378-25	PAS	NJDEP 15001	8/6/2021	5:21	SM 3113 B	8/10/2021	10:37	0.450	2.00	1	N	ND
TCE-1-B122-CF-P	N	P21-08378-26	PAS	NJDEP 15001	8/6/2021	5:22	SM 3113 B	8/10/2021	10:49	0.0055	2.00	1	N	ND
TCE-1-B121-CF-P	N	P21-08378-27	PAS	NJDEP 15001	8/6/2021	5:23	SM 3113 B	8/10/2021	10:53	3.75	2.00	1	N	
TCE-1-B123-CF-P	N	P21-08378-28	PAS	NJDEP 15001	8/6/2021	5:24	SM 3113 B	8/10/2021	10:57	1.55	2.00	1	N	J
<b>TCE-1-B126-CF-P</b>	<b>N</b>	<b>P21-08378-29</b>	<b>PAS</b>	<b>NJDEP 15001</b>	<b>8/6/2021</b>	<b>5:26</b>	<b>SM 3113 B</b>	<b>8/10/2021</b>	<b>13:14</b>	<b>16.3</b>	<b>4.00</b>	<b>2</b>	<b>Y</b>	
TCE-1-B125-CF-P	N	P21-08378-30	PAS	NJDEP 15001	8/6/2021	5:26	SM 3113 B	8/10/2021	11:06	0.450	2.00	1	N	ND
TCE-1-B116-CF-P	N	P21-08378-31	PAS	NJDEP 15001	8/6/2021	5:27	SM 3113 B	8/10/2021	11:10	1.33	2.00	1	N	J
TCE-1-B111-CF-P	N	P21-08378-32	PAS	NJDEP 15001	8/6/2021	5:28	SM 3113 B	8/10/2021	11:14	0.890	2.00	1	N	ND
TCE-1-B114-CF-P	N	P21-08378-33	PAS	NJDEP 15001	8/6/2021	5:29	SM 3113 B	8/10/2021	11:18	0.670	2.00	1	N	ND
TCE-1-B112-CF-P	N	P21-08378-34	PAS	NJDEP 15001	8/6/2021	5:30	SM 3113 B	8/10/2021	11:22	1.11	2.00	1	N	J

**Appendix D**  
Excel Template for Lead Results

Client : PARS Environmental  
Project ID : Town Center Elementary - 700 Wyndhurst Dr.

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
TCE-1-B109-CF-P	N	P21-08378-35	PAS	NJDEP 15001	8/6/2021	5:32	SM 3113 B	8/10/2021	11:35	7.50	2.00	1	N	
TCE-1-HB110-BT-P	N	P21-08378-36	PAS	NJDEP 15001	8/6/2021	5:33	SM 3113 B	8/10/2021	11:39	0.0055	2.00	1	N	ND
TCE-1-B108-CF-P	N	P21-08378-37	PAS	NJDEP 15001	8/6/2021	5:34	SM 3113 B	8/10/2021	11:43	1.99	2.00	1	N	J
TCE-2-B203-TL-P	N	P21-08378-38	PAS	NJDEP 15001	8/6/2021	5:41	SM 3113 B	8/10/2021	11:47	3.97	2.00	1	N	
TCE-2-B205-CF-P	N	P21-08378-39	PAS	NJDEP 15001	8/6/2021	5:42	SM 3113 B	8/10/2021	13:18	23.2	6.00	3	N	
TCE-2-B204-CF-P	N	P21-08378-40	PAS	NJDEP 15001	8/6/2021	5:43	SM 3113 B	8/10/2021	11:55	0.890	2.00	1	N	ND
TCE-2-B207-CF-P	N	P21-08378-41	PAS	NJDEP 15001	8/6/2021	5:43	SM 3113 B	8/10/2021	11:59	5.07	2.00	1	N	
TCE-2-B206-CF-P	N	P21-08378-42	PAS	NJDEP 15001	8/6/2021	5:44	SM 3113 B	8/10/2021	12:22	3.53	2.00	1	N	
TCE-2-B209-CF-P	N	P21-08378-43	PAS	NJDEP 15001	8/6/2021	5:45	SM 3113 B	8/10/2021	12:26	1.77	2.00	1	N	J
TCE-2-B208-CF-P	N	P21-08378-44	PAS	NJDEP 15001	8/6/2021	5:46	SM 3113 B	8/10/2021	12:30	0.670	2.00	1	N	ND
TCE-2-B210-CF-P	N	P21-08378-45	PAS	NJDEP 15001	8/6/2021	5:47	SM 3113 B	8/10/2021	12:34	0.670	2.00	1	N	ND
TCE-2-B225-CF-P	N	P21-08378-46	PAS	NJDEP 15001	8/6/2021	5:49	SM 3113 B	8/10/2021	12:38	1.55	2.00	1	N	J
TCE-2-HT35-BT-P	N	P21-08378-47	PAS	NJDEP 15001	8/6/2021	5:50	SM 3113 B	8/10/2021	12:42	-0.21	2.00	1	N	ND
TCE-2-B228-CF-P	N	P21-08378-48	PAS	NJDEP 15001	8/6/2021	5:51	SM 3113 B	8/10/2021	12:46	1.11	2.00	1	N	J
TCE-2-B226-CF-P	N	P21-08378-49	PAS	NJDEP 15001	8/6/2021	5:52	SM 3113 B	8/10/2021	12:50	0.450	2.00	1	N	ND
TCE-2-B223-CF-P	N	P21-08378-50	PAS	NJDEP 15001	8/6/2021	5:52	SM 3113 B	8/9/2021	14:17	-0.32	2.00	1	N	ND
TCE-2-B221-CF-P	N	P21-08378-51	PAS	NJDEP 15001	8/6/2021	5:53	SM 3113 B	8/9/2021	14:21	-0.55	2.00	1	N	ND
TCE-2-B217-CF-P	N	P21-08378-52	PAS	NJDEP 15001	8/6/2021	5:54	SM 3113 B	8/9/2021	14:25	0.840	2.00	1	N	ND
TCE-2-B215-CF-P	N	P21-08378-53	PAS	NJDEP 15001	8/6/2021	5:55	SM 3113 B	8/9/2021	14:30	3.60	2.00	1	N	
TCE-2-B220-CF-P	N	P21-08378-54	PAS	NJDEP 15001	8/6/2021	5:56	SM 3113 B	8/9/2021	14:34	4.76	2.00	1	N	
TCE-2-B213-CF-P	N	P21-08378-55	PAS	NJDEP 15001	8/6/2021	5:56	SM 3113 B	8/9/2021	14:38	1.07	2.00	1	N	J
TCE-2-B218-CF-P	N	P21-08378-56	PAS	NJDEP 15001	8/6/2021	5:57	SM 3113 B	8/9/2021	14:42	1.30	2.00	1	N	J
TCE-2-B211-CF-P	N	P21-08378-57	PAS	NJDEP 15001	8/6/2021	5:58	SM 3113 B	8/9/2021	14:46	1.07	2.00	1	N	J
TCE-2-B216-CF-P	N	P21-08378-58	PAS	NJDEP 15001	8/6/2021	5:59	SM 3113 B	8/9/2021	14:50	0.840	2.00	1	N	ND
TCE-2-HT32-BT-P	N	P21-08378-59	PAS	NJDEP 15001	8/6/2021	6:00	SM 3113 B	8/9/2021	15:02	-0.78	2.00	1	N	ND
TCE-2-B214-CF-P	N	P21-08378-60	PAS	NJDEP 15001	8/6/2021	6:00	SM 3113 B	8/9/2021	15:06	-0.55	2.00	1	N	ND
TCE-2-B212-CF-P	N	P21-08378-61	PAS	NJDEP 15001	8/6/2021	6:01	SM 3113 B	8/9/2021	15:10	0.610	2.00	1	N	ND

Exceeds EPA Action Limit (> 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)rimary / (F)lush

OUTLET TYPE

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib



## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

Village Elementary School  
601 New Village Road, West Windsor Township, NJ 08550

Dear Village School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Village Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 50 samples taken, all tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]). No exceedances were detected above the action limit in Village Elementary School.

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : WWP - Village School

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
VES-Field Blank	N	P21-09472-01	PAS	NJDEP 15001	8/25/2021	5:01	SM 3113 B	8/26/2021	8:26	-0.23	2.00	1	N	ND
VES-1-FacDr-TL-P	N	P21-09472-02	PAS	NJDEP 15001	8/25/2021	5:02	SM 3113 B	8/26/2021	8:30	0.190	2.00	1	N	ND
VES-1-Kit-FP1-P	N	P21-09472-03	PAS	NJDEP 15001	8/25/2021	5:03	SM 3113 B	8/26/2021	8:53	0.190	2.00	1	N	ND
VES-1-Kit-FP2-P	N	P21-09472-04	PAS	NJDEP 15001	8/25/2021	5:05	SM 3113 B	8/26/2021	8:57	0.190	2.00	1	N	ND
VES-1-Kit-FP3-P	N	P21-09472-05	PAS	NJDEP 15001	8/25/2021	5:06	SM 3113 B	8/26/2021	9:01	0.190	2.00	1	N	ND
VES-1-Kit-KT2-P	N	P21-09472-06	PAS	NJDEP 15001	8/25/2021	5:08	SM 3113 B	8/26/2021	9:05	1.42	2.00	1	N	J
VES-1-Kit-IM-P	N	P21-09472-07	PAS	NJDEP 15001	8/25/2021	5:14	SM 3113 B	8/26/2021	9:09	-0.23	2.00	1	N	ND
VES-1-H Caf-BT-P	N	P21-09472-08	PAS	NJDEP 15001	8/25/2021	5:17	SM 3113 B	8/26/2021	9:13	-0.43	2.00	1	N	ND
VES-1-MO-TL1-P	N	P21-09472-09	PAS	NJDEP 15001	8/25/2021	5:18	SM 3113 B	8/26/2021	9:17	1.01	2.00	1	N	J
VES-1-MO-TL2-P	N	P21-09472-10	PAS	NJDEP 15001	8/25/2021	5:19	SM 3113 B	8/26/2021	9:21	0.390	2.00	1	N	ND
VES-1-A30-TL-P	N	P21-09472-11	PAS	NJDEP 15001	8/25/2021	5:20	SM 3113 B	8/26/2021	9:25	3.28	2.00	1	N	
VES-1-B102-TL-P	N	P21-09472-12	PAS	NJDEP 15001	8/25/2021	5:26	SM 3113 B	8/26/2021	9:38	2.04	2.00	1	N	
VES-1-B104-CF-P	N	P21-09472-13	PAS	NJDEP 15001	8/25/2021	5:27	SM 3113 B	8/26/2021	9:42	2.66	2.00	1	N	
VES-1-B105-CF-P	N	P21-09472-14	PAS	NJDEP 15001	8/25/2021	5:28	SM 3113 B	8/26/2021	9:46	2.04	2.00	1	N	
VES-1-B107-CF-P	N	P21-09472-15	PAS	NJDEP 15001	8/25/2021	5:29	SM 3113 B	8/26/2021	9:50	0.800	2.00	1	N	ND
VES-1-B106-CF-P	N	P21-09472-16	PAS	NJDEP 15001	8/25/2021	5:29	SM 3113 B	8/26/2021	9:54	0.600	2.00	1	N	ND
VES-1-B108-CF-P	N	P21-09472-17	PAS	NJDEP 15001	8/25/2021	5:30	SM 3113 B	8/26/2021	9:58	13.2	2.00	1	N	
VES-1-B109-CF-P	N	P21-09472-18	PAS	NJDEP 15001	8/25/2021	5:31	SM 3113 B	8/26/2021	10:02	3.28	2.00	1	N	
VES-1-B110-CF-P	N	P21-09472-19	PAS	NJDEP 15001	8/25/2021	5:33	SM 3113 B	8/26/2021	10:06	2.25	2.00	1	N	
VES-1-B112-CF-P	N	P21-09472-20	PAS	NJDEP 15001	8/25/2021	5:35	SM 3113 B	8/26/2021	10:11	2.25	2.00	1	N	
VES-1-B111-CF-P	N	P21-09472-21	PAS	NJDEP 15001	8/25/2021	5:36	SM 3113 B	8/26/2021	10:23	14.8	2.00	1	N	
VES-1-B114-CF-P	N	P21-09472-22	PAS	NJDEP 15001	8/25/2021	5:37	SM 3113 B	8/26/2021	10:39	5.55	2.00	1	N	
VES-1-B116-CF-P	N	P21-09472-23	PAS	NJDEP 15001	8/25/2021	5:38	SM 3113 B	8/26/2021	10:43	3.07	2.00	1	N	
VES-1-B118-CF-P	N	P21-09472-24	PAS	NJDEP 15001	8/25/2021	5:39	SM 3113 B	8/26/2021	10:47	3.48	2.00	1	N	
VES-1-B113-CF-P	N	P21-09472-25	PAS	NJDEP 15001	8/25/2021	5:40	SM 3113 B	8/26/2021	10:50	13.2	2.00	1	N	
VES-1-B115-CF-P	N	P21-09472-26	PAS	NJDEP 15001	8/25/2021	5:41	SM 3113 B	8/26/2021	10:54	14.6	2.00	1	N	
VES-1-B120-CF-P	N	P21-09472-27	PAS	NJDEP 15001	8/25/2021	5:42	SM 3113 B	8/26/2021	11:06	4.31	2.00	1	N	
VES-1-B122-CF-P	N	P21-09472-28	PAS	NJDEP 15001	8/25/2021	5:43	SM 3113 B	8/26/2021	11:10	2.25	2.00	1	N	
VES-1-H B121-BT-P	N	P21-09472-29	PAS	NJDEP 15001	8/25/2021	5:45	SM 3113 B	8/26/2021	11:14	-0.23	2.00	1	N	ND
VES-1-B124-CF-P	N	P21-09472-30	PAS	NJDEP 15001	8/25/2021	5:47	SM 3113 B	8/26/2021	11:18	1.01	2.00	1	N	J
VES-1-B124B-CF-P	N	P21-09472-31	PAS	NJDEP 15001	8/25/2021	5:48	SM 3113 B	8/26/2021	11:22	1.01	2.00	1	N	J
VES-2-B205-CF-P	N	P21-09472-32	PAS	NJDEP 15001	8/25/2021	5:53	SM 3113 B	8/26/2021	11:26	2.66	2.00	1	N	
VES-2-B204-CF-P	N	P21-09472-33	PAS	NJDEP 15001	8/25/2021	5:54	SM 3113 B	8/26/2021	11:30	0.800	2.00	1	N	ND
VES-2-B207-CF-P	N	P21-09472-34	PAS	NJDEP 15001	8/25/2021	5:55	SM 3113 B	8/26/2021	11:34	0.800	2.00	1	N	ND
VES-2-B206-CF-P	N	P21-09472-35	PAS	NJDEP 15001	8/25/2021	5:56	SM 3113 B	8/26/2021	12:09	14.2	2.00	1	N	
VES-2-B209-CF-P	N	P21-09472-36	PAS	NJDEP 15001	8/25/2021	5:57	SM 3113 B	8/26/2021	12:13	1.42	2.00	1	N	J
VES-2-B208-CF-P	N	P21-09472-37	PAS	NJDEP 15001	8/25/2021	5:58	SM 3113 B	8/26/2021	12:17	3.07	2.00	1	N	
VES-2-B214-CF-P	N	P21-09472-38	PAS	NJDEP 15001	8/25/2021	5:59	SM 3113 B	8/26/2021	12:21	9.67	2.00	1	N	
VES-2-B216-CF-P	N	P21-09472-39	PAS	NJDEP 15001	8/25/2021	6:00	SM 3113 B	8/26/2021	12:25	1.01	2.00	1	N	J
VES-2-B211-CF-P	N	P21-09472-40	PAS	NJDEP 15001	8/25/2021	6:02	SM 3113 B	8/26/2021	12:29	2.04	2.00	1	N	
VES-2-B218-CF-P	N	P21-09472-41	PAS	NJDEP 15001	8/25/2021	6:03	SM 3113 B	8/26/2021	12:41	3.28	2.00	1	N	
VES-2-B213-CF-P	N	P21-09472-42	PAS	NJDEP 15001	8/25/2021	6:04	SM 3113 B	8/26/2021	12:45	14.0	2.00	1	N	
VES-2-B215-CF-P	N	P21-09472-43	PAS	NJDEP 15001	8/25/2021	6:05	SM 3113 B	8/26/2021	12:49	1.22	2.00	1	N	J
VES-2-B228-CF-P	N	P21-09472-44	PAS	NJDEP 15001	8/25/2021	6:08	SM 3113 B	8/26/2021	12:53	1.42	2.00	1	N	J
VES-2-B230-CF-P	N	P21-09472-45	PAS	NJDEP 15001	8/25/2021	6:09	SM 3113 B	8/26/2021	12:57	1.01	2.00	1	N	J
VES-2-B221-CF-P	N	P21-09472-46	PAS	NJDEP 15001	8/25/2021	6:10	SM 3113 B	8/26/2021	13:01	1.01	2.00	1	N	J
VES-2-B223-CF-P	N	P21-09472-47	PAS	NJDEP 15001	8/25/2021	6:11	SM 3113 B	8/26/2021	13:05	1.01	2.00	1	N	J
VES-2-B225-CF-P	N	P21-09472-48	PAS	NJDEP 15001	8/25/2021	6:12	SM 3113 B	8/26/2021	13:09	1.84	2.00	1	N	J
VES-2-B232-CF-P	N	P21-09472-49	PAS	NJDEP 15001	8/25/2021	6:13	SM 3113 B	8/26/2021	13:14	0.600	2.00	1	N	ND
VES-2-H B234-BT-P	N	P21-09472-50	PAS	NJDEP 15001	8/25/2021	6:14	SM 3113 B	8/26/2021	13:26	-0.23	2.00	1	N	ND





## WEST WINDSOR-PLAINSBORO REGIONAL SCHOOL DISTRICT

321 Village Road East  
West Windsor, NJ 08550  
Telephone: (609) 716-5000  
[www.ww-p.org](http://www.ww-p.org)

Sept. 7, 2021

J.V.B. Wicoff Elementary School  
510 Plainsboro Rd, Plainsboro Township, NJ 08536

Dear J.V.B Wicoff Elementary School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, West Windsor-Plainsboro Regional School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, J.V.B. Wicoff Elementary School will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

### Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within the West Windsor-Plainsboro Regional School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 31 samples taken, all but 5 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action West Windsor-Plainsboro Regional School District has taken to reduce the levels of lead at these locations.

<b>Sample Location</b>	<b>First Draw Result in µg/l (ppb)</b>	<b>Remedial Action</b>
1 <sup>st</sup> Floor Library Classroom Faucet ID # JVBW-1-RM 26 Library-CF-P	32.2	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom Faucet ID# JVBW-1-RM 6-CF-P	16.9	Disconnected outlet until further notice
1 <sup>st</sup> Floor Classroom Faucet ID # JVBW-1-RM 4-CF-P	60.7	Disconnected outlet until further notice

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

Sample Location	First Draw Result in µg/l (ppb)	Remedial Action
2 <sup>nd</sup> Floor Classroom Faucet ID # JVBW-2-RM 21A-CF-P	28.1	Disconnected outlet until further notice
2 <sup>nd</sup> Floor Classroom Faucet ID # JVBW-2-RM 20- CF-P	58.4	Disconnected outlet until further notice

### Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

### How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

### Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

### For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 4:00 p.m. and are also available on our website at [www.wv-p.org](http://www.wv-p.org). For more information about water quality in our schools, contact Thomas Daly, Director of Buildings & Grounds at 609-455-3863 at West Windsor-Plainsboro Regional School District.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at [www.epa.gov/lead](http://www.epa.gov/lead), call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

Sincerely,  
Thomas Daly, CEFM  
Director of Buildings & Grounds

Building upon our tradition of excellence, the mission of the West Windsor-Plainsboro Regional School District is to empower all learners to thoughtfully contribute to a diverse and changing world with confidence, strength of character, and love of learning.

**Appendix D**  
**Excel Template for Lead Results**

Client : PARS Environmental  
Project ID : WWP Wicoff - 510 Plainsboro Rd.

Field ID	Flushed (Y/N)	Lab. Sample ID	Lab. Name	Lab. ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Conc. (ug/L)	Rpt. Limit (ug/L)	DF	Digested (Y/N)	Qfr.
JVBW Field Blank	N	P21-08377-01	PAS	NJDEP 15001	8/6/2021	4:50	SM 3113 B	8/9/2021	8:04	-0.32	2.00	1	N	ND
JVBW-1 Kitch Sink FP1-P	N	P21-08377-02	PAS	NJDEP 15001	8/6/2021	4:55	SM 3113 B	8/9/2021	8:08	-0.09	2.00	1	N	ND
JVBW-1 Kitch Sink FP2-P	N	P21-08377-03	PAS	NJDEP 15001	8/6/2021	4:45	SM 3113 B	8/9/2021	8:45	0.140	2.00	1	N	ND
JVBW-1 Rm 23 CF-P	N	P21-08377-04	PAS	NJDEP 15001	8/6/2021	5:02	SM 3113 B	8/9/2021	8:49	1.76	2.00	1	N	J
JVBW-1 Rm 18 CF-P	N	P21-08377-05	PAS	NJDEP 15001	8/6/2021	5:03	SM 3113 B	8/9/2021	8:53	2.68	2.00	1	N	
JVBW-1-Cafe BT-P	N	P21-08377-06	PAS	NJDEP 15001	8/6/2021	5:06	SM 3113 B	8/9/2021	8:57	-0.32	2.00	1	N	ND
JVBW-1-Cafe CF-P	N	P21-08377-07	PAS	NJDEP 15001	8/6/2021	5:07	SM 3113 B	8/9/2021	9:01	4.76	2.00	1	N	
JVBW-1-Nurse NS-P	N	P21-08377-08	PAS	NJDEP 15001	8/6/2021	5:07	SM 3113 B	8/9/2021	9:05	0.370	2.00	1	N	ND
JVBW-1-HMO-BT-P	N	P21-08377-09	PAS	NJDEP 15001	8/6/2021	5:09	SM 3113 B	8/9/2021	9:09	-0.32	2.00	1	N	ND
JVBW-1-RM 15 CF-P	N	P21-08377-10	PAS	NJDEP 15001	8/6/2021	5:11	SM 3113 B	8/9/2021	9:21	0.370	2.00	1	N	ND
JVBW-1-RM 9 CF-P	N	P21-08377-11	PAS	NJDEP 15001	8/6/2021	5:12	SM 3113 B	8/9/2021	9:25	-0.09	2.00	1	N	ND
JVBW-1-RM 10 CF-P	N	P21-08377-12	PAS	NJDEP 15001	8/6/2021	5:13	SM 3113 B	8/9/2021	9:29	0.370	2.00	1	N	ND
JVBW-1-RM 11 CF-P	N	P21-08377-13	PAS	NJDEP 15001	8/6/2021	5:14	SM 3113 B	8/9/2021	9:33	0.370	2.00	1	N	ND
JVBW-1-RM 12 CF-P	N	P21-08377-14	PAS	NJDEP 15001	8/6/2021	5:15	SM 3113 B	8/9/2021	9:37	1.07	2.00	1	N	J
JVBW-1-RM 13 CF-P	N	P21-08377-15	PAS	NJDEP 15001	8/6/2021	5:16	SM 3113 B	8/9/2021	9:42	1.76	2.00	1	N	J
JVBW-1-RM 14 CF-P	N	P21-08377-16	PAS	NJDEP 15001	8/6/2021	5:16	SM 3113 B	8/9/2021	9:46	2.68	2.00	1	N	
JVBW-1-RM 33 CF-P	N	P21-08377-17	PAS	NJDEP 15001	8/6/2021	5:19	SM 3113 B	8/9/2021	9:50	3.60	2.00	1	N	
JVBW-1-RM 24 CF-P	N	P21-08377-18	PAS	NJDEP 15001	8/6/2021	5:20	SM 3113 B	8/9/2021	9:54	1.53	2.00	1	N	J
JVBW-1-RM 25 CF-P	N	P21-08377-19	PAS	NJDEP 15001	8/6/2021	5:21	SM 3113 B	8/9/2021	10:06	6.60	2.00	1	N	
JVBW-1-RM 26 Library CF-P	N	P21-08377-20	PAS	NJDEP 15001	8/6/2021	5:22	SM 3113 B	8/9/2021	10:41	<b>32.2</b>	6.00	3	N	
JVBW-1-RM 1 CF-P	N	P21-08377-21	PAS	NJDEP 15001	8/6/2021	5:25	SM 3113 B	8/9/2021	10:14	1.30	2.00	1	N	J
JVBW-1-RM 8 CF-P	N	P21-08377-22	PAS	NJDEP 15001	8/6/2021	5:27	SM 3113 B	8/9/2021	10:53	6.83	2.00	1	N	
JVBW-1-RM 2 CF-P	N	P21-08377-23	PAS	NJDEP 15001	8/6/2021	5:28	SM 3113 B	8/9/2021	10:57	3.60	2.00	1	N	
JVBW-1-RM 3 CF-P	N	P21-08377-24	PAS	NJDEP 15001	8/6/2021	5:29	SM 3113 B	8/9/2021	11:01	11.0	2.00	1	N	
JVBW-1-RM 6 CF-P	N	P21-08377-25	PAS	NJDEP 15001	8/6/2021	5:30	SM 3113 B	8/9/2021	12:47	<b>16.9</b>	4.00	2	Y	
JVBW-1-RM 4 CF1-P	N	P21-08377-26	PAS	NJDEP 15001	8/6/2021	5:32	SM 3113 B	8/9/2021	11:05	6.14	2.00	1	N	
JVBW-1-RM 4 CF2-P	N	P21-08377-27	PAS	NJDEP 15001	8/6/2021	5:33	SM 3113 B	8/9/2021	12:51	<b>60.7</b>	10.0	5	N	
JVBW-1-RM 5 CF-P	N	P21-08377-28	PAS	NJDEP 15001	8/6/2021	5:33	SM 3113 B	8/9/2021	11:17	3.83	2.00	1	N	
JVBW-2-RM 22 CF-P	N	P21-08377-29	PAS	NJDEP 15001	8/6/2021	5:39	SM 3113 B	8/9/2021	11:29	7.75	2.00	1	N	
JVBW-2-RM 21A CF-P	N	P21-08377-30	PAS	NJDEP 15001	8/6/2021	5:40	SM 3113 B	8/9/2021	12:55	<b>28.1</b>	6.00	3	N	
JVBW-2-RM 2 OCF-P	N	P21-08377-31	PAS	NJDEP 15001	8/6/2021	5:40	SM 3113 B	8/9/2021	12:59	<b>58.4</b>	10.0	5	N	

Exceeds EPA Action Limit ( > 15.5ppb)

Bldg ID - Floor - Room / Location ID - Outlet Type / Number in Sequence - (P)rimary / (F)lush

**OUTLET TYPE**

- BF = Bathroom Faucet
- CF = Classroom Faucet
- DW = Drinking Water Fountain
- FP = Food Prep
- HS = Hand Sink
- IM = Ice Machine
- KC = Kitchen Outlet, Cold
- KT= Kettle
- SB = Sink/Bubbler Combination
- TF = Teachers Faucet
- WC = Water Cooler
- BT= Bottle Filler
- HB= Hose Bib